



State of New Jersey

CHRIS CHRISTIE
Governor

DEPARTMENT OF ENVIRONMENTAL PROTECTION
Bureau of Case Management
401 East State Street
P.O. Box 420/Mail Code 401-05F
Trenton, NJ 08625-0028
Phone #: 609-633-1455
Fax #: 609-633-1439

BOB MARTIN
Commissioner

KIM GUADAGNO
Lt. Governor

November 10, 2015

John Occhipinti
BRAC Environmental Coordinator
OACSIM – U.S. Army Fort Monmouth
PO Box 148
Oceanport, NJ 07757

Re: *Site Investigation Report Addendum for the 800 Area Including ECP Parcels 55 & 56*
Fort Monmouth
Oceanport, Monmouth County
PI G000000032

Dear Mr. Occhipinti:

The New Jersey Department of Environmental Protection (Department) has completed review of the referenced report, received June 22, 2015, prepared by the Department of the Army's Office of Assistant Chief of Staff for Installation Management to provide responses to NJDEP letters of September 5, 2007 and December 31, 2007.

USTs Requiring No Additional Action

Underground storage tanks within these parcels previously granted a designation of no further action (NFA) include the following:

Parcel 55

UST 1006-159
UST 826-134
UST 828-136

Parcel 56

UST 875-234
UST 876-139
UST 876-138
UST 864-136
UST 866-137

Following review of the referenced information, it is agreed no further action is necessary for the following #2 fuel USTs:


UST 800-2 (Attachment G)
UST-800-10 (Attachment I)
UST-800-14 (Attachment K)
UST 800-15 (Attachment L)
UST-800-16 (Attachment M)
UST-800-19 (Attachment N)
UST 800-22 (Attachment Q)
UST 850 (Attachment T)

USTs Requiring Additional Remedial Efforts

Based upon soil contamination extending to within 2' of, and in some cases, into the ground water table (GWT), a ground water investigation in accordance with the Technical Rules for Site Remediation is necessary at the following UST locations. Unless otherwise indicated, analytical parameters are to include VOs+TICs and SVOs+TICs (N.J.A.C. 7:26E-2.1, Table 2-1).

UST 800-1 – Attachment F – Parcel 55 - #03-07-30-1431
UST 800-9 – Attachment H – Parcel 55 - #04-05-20-1615-42
UST 800-12 – Attachment J – Parcel 55 - #04-05-25-1623-31
UST-800-20 – Attachment O – Parcel 56 - #03-07-30-1431
UST 800-21 – Attachment P – Parcel 56 - #03-09-11-0906-50
UST 813 – Attachment R – Parcel 54 - #10-12-17-1533-15
UST 814 – Attachment S – Parcel 54 – It is agreed the submitted soil analytical results, which indicate no exceedences are present, were likely collected at Building 814. Although ground water analytical results indicate no exceedences of #2 fuel related constituents, the anomalous Oct '92 GW results cannot be dismissed. Therefore, collection of a ground water sample for VOs+TICs analyses is required.
UST 884 – Attachment U – Parcel 57 - #03-10-07-1347-49
UST 888 – Attachment V – Parcel 56 - #11-01-05-1416-41

Please contact this office if you have any questions.

Sincerely,

Linda S. Range

C: Joe Pearson, Calibre
Rich Harrison, FMERA
Joe Fallon, FMERA
James Moore, USACE
Frank Barricelli, RAB