



State of New Jersey

CHRIS CHRISTIE
Governor

KIM GUADAGNO
Lt. Governor

DEPARTMENT OF ENVIRONMENTAL PROTECTION
Bureau of Case Management
401 East State Street
P.O. Box 420/Mail Code 401-05F
Trenton, NJ 08625-0028
Phone #: 609-633-1455
Fax #: 609-633-1439

BOB MARTIN
Commissioner

May 30, 2013

Wanda Green
BRAC Environmental Coordinator
OACSIM – U.S. Army Fort Monmouth
PO Box 148
Oceanport, NJ 07757

Re: Army's January 31, 2013 Correspondence – Miscellaneous USTs
Main Post & Charles Wood Area
Fort Monmouth, New Jersey
PI G000000032

Dear Ms. Green:

The New Jersey Department of Environmental Protection (Department) has completed review of the referenced correspondence (and associated Attachments A through T), submitted to address several of the unresolved underground storage tank (UST) issues noted in this office's letter of July 10, 2012. As indicated in the referenced submittal, additional information regarding the various USTs will be forthcoming. The following comments are offered.

Parcel 28 – Former Eatontown Laboratory

As has been discussed, it is agreed no additional action is necessary for UST 2539-28, UST 2539-64, UST 2531-21, and two of the three USTs previously located between Building 2525 and Heliport Drive. Documentation as to the adequate evaluation of tanks UST 2542-29, UST 2564-32 and the UST at Building 2544 (T-7) has not yet been submitted.

Parcel 49 – Former Squier Laboratory Complex

Upon review of the documentation included in the submittal, it is agreed no further action is necessary for the UST at Building 293-67, or UST 283B-59.

Parcel 51 – 750 Area, 500 Area, 600 Area, 1100 Area – Former Buildings

Upon review of the documentation included in the submittal, it is agreed no further action is necessary for UST 695-111, UST 635, UST 642, UST 643 and 501-76.

As no sampling was apparently performed at UST 637, this office cannot concur there has been no discharge associated with the UST. As regarding Appendix K, and USTs at Buildings 644 through 654, evidently no sampling was performed; again, without same, this office cannot concur there has been no discharge.

Parcel 76 – 200 Area, 300 Area – Former Barracks

Review of the documentation included in the submittal indicates no additional action is necessary for UST 261 and UST 261B.


Parcel 79 – 400 Area Former Barracks

Review of the documentation included in the submittal, as well as that included in the files, indicates no further action is necessary for UST 411-28, UST 421-37, UST 423-39

As no sampling was evidently performed at UST 401-26 or UST 416-32, this office cannot concur there has been no discharge associated with the USTs.

If you have any questions regarding this matter, please contact this office at (609) 984-6606.

Sincerely,



Linda S. Range
Bureau of Case Management

C: Joe Pearson, Calibre Systems
Rich Harrison, FMERA
Julie Carver, Matrix