

Friesen, Kent

From: Range, Linda <Linda.Range@dep.nj.gov>
Sent: Monday, April 17, 2017 10:52 AM
To: Pearson, Joe
Cc: Briggs, James E CIV (US); Briggs, James E CIV (US); Colvin, William R Jr CIV (US); Friesen, Kent; Occhipinti, John E CIV USARMY HQDA ACSIM (US); Moore, James T NAN02 (James.T.Moore@usace.army.mil); Clark, Daryl
Subject: RE: Fort Monmouth USTs at Marina Area

Joe,

As requested, the review of those tanks at the marina area was completed (comments regarding PAHs in the other areas are pending).

The geologist's comments regarding his review of UST 202A and 202D area are that the permanent well non-detects for PAHs is not relevant due to their lack of proximity (60' +) to the USTs in question.

I re-read my March 30, 2016 comments regarding the workplan for these USTs. In that comment letter I'd stated (I added underline for prominence just now) "Sampling as proposed is approved. To clarify, however, it is assumed elevated levels of ground water contamination remain at UST 202D, and proposed sample located downgradient is for delineation purposes." Therefore, it was to be stipulated ground water contamination remained at the UST, which would render it ineligible for nfa.

Recommendations – install a permanent well at location immediately downgradient of UST 202D. Analyses required for VO and SVOCs; SVOCs should be collected via low-flow.

Let me know if you have any questions.

Linda Range
NJDEP
Bureau of Case Management
609-984-6606

From: Pearson, Joe [mailto:Joseph.Pearson@calibresys.com]
Sent: Tuesday, April 11, 2017 11:06 AM
To: Range, Linda <Linda.Range@dep.nj.gov>
Cc: Briggs, James E CIV (US) <james.e.briggs2.civ@mail.mil>; Briggs, James E CIV (US) <james.e.briggs2.civ@mail.mil>; Colvin, William R Jr CIV (US) <william.r.colvin18.civ@mail.mil>; Friesen, Kent <Kent.Friesen@parsons.com>; Occhipinti, John E CIV USARMY HQDA ACSIM (US) <john.e.occhipinti.civ@mail.mil>
Subject: Fort Monmouth USTs at Marina Area

Linda:

As discussed on the conference call this morning, the Army would like to request a priority on the evaluation of tanks at the Marina (which is part of Parcel 79). These are tanks 202A and 202D and are covered in the attached letter report on pages 6 and 7 wherein the Army has requested NFA for these tanks.

This would allow the Army to proceed with preparing the FOST and transferring the Marina property.

Thanks.

Joseph Pearson
CALIBRE Systems
215-699-4490
Mobile: 267-251-7214