



DEPARTMENT OF THE ARMY

HEADQUARTERS, U.S. ARMY GARRISON FORT MONMOUTH

FORT MONMOUTH, NEW JERSEY 07703-5101



August 26, 2009

From: Howard M. Syvarth, TVS Hydrogeologist
To: UST file
Subject: UST Closure Reports for Building 2236/Tank Registration #: 81515-6

Enclosed are the file review sheets for the closure of the Underground Storage Tank(s) (USTs) located at the above referenced location. After performing a file review to include submittals to NJDEP, I have determined that the tank closure and the subsequent report meet the minimum requirements established by NJDEP and as such are considered to be closed by both NJDEP and the Directorate of Public Works, US Army Garrison Fort Monmouth.

This document serves as the official site closure. All supporting documentation for the closure of this site can be found in the UST folder located in the library archive in Bldg. 173, Fort Monmouth, New Jersey.

Any questions regarding the information found in this or any other UST folder should be directed to:

Howard M. Syvarth
TECOM-Vinnell Services (TVS)
Staff Hydrogeologist, UST program
Directorate of Public Works, Ft. Monmouth, NJ
Email: Howard.M.Syvarth@us.army.mil

Sincerely,

Howard M. Syvarth
TVS Staff Hydrogeologist

Mr. Charles Appleby
Subsurface Evaluator NJDEP #9974
Environmental Protection Specialist
Directorate of Public Works

U.S. ARMY FORT MONMOUTH
UST DATABASE INPUT FORM
SELEM-EH-EV

CA

DATE: 11/9/94 BUILDING #: 2236
NJDEPE REG. #: 81515 UST #: 6
PRODUCT: (#2), #6, DIESEL, GASOLINE, OTHER, _____
STATUS: IN USE, NOT IN USE AS OF 11/9/94
REASON NOT IN USE: (GASIFICATION), LEAKER, DEMO
GENERAL COMMENTS:

UST PRODUCT REMOVED: DATE: 11/9/94
CONTRACTOR: SERVAIR P.O.L. T. Smythe
MANIFEST #: NONE
COMMENTS: 26 GALS WASTE IN TANK
192 GALS TO BLDG 2700

NJDEPE DISCHARGE TO ENVIRONMENT NOTIFICATION
(609) 292-7172,
CALLER NAME: _____

DATE: _____ TIME: _____

NJDEPE CASE NUMBER: _____

COMMENTS: _____

ATTACHMENTS (COPIES): HAZ-MAT MANIFEST,
LAND BAN SERVICE ORDER PURCHASE REQ
SPILL REPORT

SUBMITTED BY: _____

SIGNATURE: _____ DATE: _____

Fort Monmouth UST Status Summary Report

UST REGISTRATION INFORMATION SUMMARY

LOCATION: 2236 **NJDEP REG ID:** 81515-6
RESIDENTIAL? YES

UST CONSTRUCTION INFORMATION SUMMARY

SIZE (GALLONS): 550 **CONSTRUCTION:** FRP
PRODUCT: #2 FUEL OIL **YEAR INSTALLED:** 1985

UST REMOVAL/INVESTIGATION SUMMARY

REMOVAL DATE: 11/16/1999 **REMOVAL CONTRACTOR:** TVS
SRF SEND DATE: **TMS:**
DICAR NO. **LEAK DETECT:** N/A
REMEDATION COMMENTS: 11/09/94 SAI removed 192 gallons of oil; left 26 gallons of waste in tank. Residential UST with no contamination and no DICAR; no Closure Report required.

REGISTRATION COMMENTS:

SAS DONE: **CONSULTANT:** TVS
MW_s NEEDED: 0 **MONITORING WELLS:** 0
SUB-SURFACE EVALUATOR: D. Desai

CURRENT UST STATUS

UST STATUS: Removed; Report Submitted/Not Nec. **CASE STATUS:** Case Closed
SUBMITTAL DATE: **APPROVAL DATE:**

Fort Monmouth Underground Storage Tank Assessment Questionnaire

Site Name: 2236 -

Is the UST Residential: YES

There is / are 1 UST(s) located at this site.

CASE STATUS: *Case Closed*

NFA ISSUED:

File Review Date: 10/27/08

By: Howard Synark

This NJDEP UST Registration # is: 81515 - 6 to _____

This UST was 550 Gallons in size, was made of FRP and contained #2 FUEL OIL.

The UST was installed in 1985 _____ and removed by TVS _____ on 11/16/1999 _____. A

Standard Reporting Form was sent to the NJDEP on _____. NJDEP Closure # _____

Subsurface Evaluator: *D. Desai* _____ NJDEP # _____

A Site Investigation Report was completed by TVS _____ and submitted to the NJDEP on _____.

The Current Status is: *Removed; Report Submitted/Not Nec.*

The Revised Status as of _____ completed by _____ is:

The Current UST Database Comments are: *11/09/94 SAI removed 192 gallons of oil; left 26 gallons of waste in tank. Residential UST with no contamination and no DICAR; no Closure Report required.*

The Revised Comments as of 10/27/08 completed by Howard Synark is:

- no NFA issued, no discharge to DEP. Non-regulated residential UST

Database updated on _____ by _____.

Remedial Phases: PA SI RI RAW CEA NFA

Project transferred to the Fort Monmouth Restoration Program

Project # FTMM- _____

Fort Monmouth Underground Storage Tank Assessment Questionnaire

1. Has the property been or is the property currently the subject of any remediation with NJDEP oversight? Yes No

If Yes, provide the following:

Case Number _____

Case Lead (US Army) _____

Case Manager (NJDEP) _____

Case Status Data base " *Case Closed* ", As of this date: _____

2. Was a Preliminary Assessment (PA) performed in accordance with N.J.A.C. 7:26E-3.1? Yes No

3. Were any Areas of Concern (AOCs) identified? Yes No
If yes proceed to question 4. If no, proceed to Check List (page 8).

4. Were any potentially contaminated AOCs identified? Yes No

List and describe all **potentially contaminated** AOCs.

UST Area Underground Piping Area Dispenser Area UST Fill Area

5. List and describe all AOCs subject to the 7:26E Regulations.
UST Area Underground Piping Area Dispenser Area UST Fill Area
-
-

6. Was a discharge of a hazardous substance, contaminant or pollutant identified? Yes No

If so, was the discharge to: (check all that apply)

Soil Ground Water Surface Water Ecologically Sensitive Area

Other (specify) _____

Fort Monmouth Underground Storage Tank Assessment Questionnaire

7. How was the discharge identified? (check all that apply)
Sample Analysis [] Olfactory [] Visual [] Record/ Loss of Product [] Field Analysis []
Other [] (specify) _____
8. What was the source of the discharge?
UST Area [] Underground Piping Area [] Dispenser Area [] UST Fill Area []

9. Were any of the following conditions present? (Check all that apply.)
Soil Staining [] Distressed or Dead Vegetation [] Product Entering Storm Sewer []
Product Entering Basement [] Off-site Migration [] Product Observed on Surface Water []
Other [] (specify) _____
10. Were samples collected in accordance with the provisions of N.J.A.C. 7:26E and the Department's applicable Field Sampling Procedures Manual? Yes [] No
TPHC VOA+10 [] BN+15 [] lead [] PP+40 []
Other: _____
11. Were soil samples collected at the appropriate depth as per N.J.A.C. 7:26E Yes [] No
12. Were samples biased toward the most contaminated areas using field Instruments and/or visual and olfactory observations? Yes [] No
How was this accomplished? _____
13. If only TPHC samples taken, were samples >1000mg/kg run for VOA+10? [] Yes No
all samples were < 1,000 ppm
14. Was the vertical and horizontal extent of soil contamination delineated prior to remediation? [] Yes No
Explain: *none required*

Fort Monmouth Underground Storage Tank Assessment Questionnaire

15. Fully describe the method of remediation?

Source Removal and Disposal [] Free Product removal by Vacuum Truck []

Other: _____

16. If excavation was performed, what was the depth of the bottom of the excavation? ~ 7 feet.

17. What is the approximate depth to saturated zone (seasonally high water table)? _____ feet.

How was this determined? Observed Measurement [] Monitoring Well []

Other: _____

18. Is the Site Tidally Impacted? [] Yes [] No

19. What is the percentage of silt/clay in the soil between the contaminant and the saturated zone?

_____. How was this determined? _____

_____ Not Available

20. Was ground water present in the excavation? [] Yes No

If yes, was there a sheen observed on ground water? [] Yes [] No

21. Are there any Public Supply Wells within 2,000 feet of confirmed soil contamination? [] Yes [] No

How was this determined? Well Search : [] _____

22. Was contaminated soil removed from the site? [] Yes No

How much soil was removed? _____ tons/cubic yards (circle one)

To what facility was the soil taken? _____

Date taken: _____

23. Were the analytical results for all soil post excavation/remediation samples below the Department's ~~June~~ Sept. 2008 residential soil cleanup criteria? Yes [] No

Fort Monmouth Underground Storage Tank Assessment Questionnaire

If No, describe in detail in Comments Page 6

22. Was this an investigation pertaining to a non-regulated heating oil tank? Yes [] No
Fort Monmouth Database : : YES
If yes, complete the following, If no go to 23

Do on-site structures have a basement/crawl space? [] Yes No

Was staining observed on the basement/crawl space walls or floor? [] Yes [] No NA

Were petroleum odors observed in the basement/crawl space? [] Yes [] No NA

Is a sump present in the basement/crawl space? [] Yes [] No NA

If yes, please indicate location on site map.

Was water observed in the sump? [] Yes [] No NA

Was a sheen observed on the water in sump? [] Yes [] No NA

If there was no water in the sump was the base of the sump investigated for a petroleum discharge? [] Yes [] No NA

If the sump was investigated, was a discharge observed? [] Yes [] No NA

23. Is a regulated underground storage tank the subject of the remediation? [] Yes No

If yes, complete the following, If no, go to 24

Was a closure approval or 14 day notification obtained prior to the closure of the tank? [] Yes [] No

List Closure Approval/Notification Numbers **NJDEP Closure #** _____

Was the closure or any remediation performed by an individual and firm certified in closure and subsurface evaluation? [] Yes [] No

Subsurface Evaluator: D. Desai _____

Individual certification number: _____

Firm certification number: _____

Was an Underground Storage Tank Facility Certification Questionnaire completed and submitted "delisting" the subject tanks? [] Yes [] No

24. Was a Baseline Ecological Evaluation conducted pursuant to N.J.A.C 7:26E? [] Yes No

If No, was the BEE a regulatory requirement at the time? [] Yes NA
 (UST removed prior to 1997 or the UST is Residential?)

If Yes, is there a contaminant of concern present? [] Yes No

Fort Monmouth Underground Storage Tank Assessment Questionnaire

- Are there environmentally sensitive natural resources within or surrounding the property? Yes No
- Are there potential contaminant migration pathways present? Yes No
- Were potential ecological impacts identified? Yes No
- Is a BEE planned to be completed for this site? Yes No
25. Was the site restored in accordance to N. J.A.C. 7:26E-6.4(b)? Yes No
26. Was the remedial investigation/action report prepared in accordance with N.J.A.C. 7:26E? Yes No
27. Remediation completed date: 11/16/99
28. Are there currently, or have there ever been, any Deed Notices or Declarations of Environmental Restriction pursuant to N.J.S.A. 58:10B-1 et seq. and N.J.A.C. 7:26E-1 et seq. for the Site? Yes No
- If yes, Attach a copy of the Deed Notice or Declaration of Environmental Restriction.**
29. Has NJDEP ever issued a no further action letter ("NFA") for any portion of the Site? Yes No
- NFA ISSUED:**
- If Yes, in accordance with N.J.S.A. 58:10B-13(e), is there an order of magnitude difference between the currently applicable remediation standard or criterion and the contaminant level approved under such previously issued NFA?** Yes No
31. Subcontractors employed during the investigation/remediation (list all):
- Name/Address: TVS
- Name/Address: TVS
- Name/Address: _____
- Name/Address: _____
- Name/Address: _____

COMMENTS:

Fort Monmouth Underground Storage Tank Assessment Questionnaire

Site Investigation - Remedial Investigation/Action Report Checklist: DATE: _____

- Soil Contamination currently exists on site Yes No JNA
- GW Contamination currently exists on site Yes No JNA
- Contaminated Soil Disposal Receipt (fully executed manifest) Yes No JNA
- Tank Disposal Certificate Yes No JNA
- Tank Contents Disposal Receipt (fully executed manifest) Yes No JNA
- Fill was "certified clean" in accordance with N.J.A.C.7:26E-6.4 Yes No JNA
- Scaled site map with AOCs and north arrow Yes No JNA
- Sample Results Summary Tables.(N.J.A.C.7:26E-4.8) Yes No JNA
- Laboratory was certified to perform the required tests Yes No JNA
- Chain of Custody forms submitted Yes No JNA
- Signed laboratory deliverables checklist and Non-Conformance Summaries submitted Yes No JNA
- Problems identified in the laboratory deliverables checklist and Non-Conformance summaries Yes No JNA
- Holding times were met for all analyses Yes No JNA
- MDLs below most stringent soil cleanup criteria Yes No JNA
- Laboratory sample summary submitted Yes No JNA
- QA/QC package (reduced deliverables) submitted Yes No JNA
- VOC soil samples methanol preserved (sample weights included) Yes No JNA
- Electronic data package (home heating oil tanks exempt) Yes No JNA
- Well search submitted Yes No JNA
- Baseline Environmental Evaluation (home heating oil tanks exempt) Yes No JNA
- Closure approval notification enclosed Yes No JNA
- No Further Action letter(s) enclosed Yes No JNA

**DIRECTORATE OF PUBLIC WORKS
FORT MONMOUTH, NEW JERSEY 07703**

Contract Management Division

SUBJECT: PWS-007, Residential UST Removal
Contractor: TVS Inc.

RE: Backfilling of excavation,


BUILDING #: 2236

TVS Inc.
Field Supervisor, PWS-007
ATTN: Brian Finch
Building 166
Fort Monmouth, New Jersey 07703-5000

Dear Mr. Finch:

The above referenced area has been sampled and analyzed as described in the NJDEP Regulations. The results indicate levels of petroleum contamination below the NJDEP allowable limits, ~~or that the site requires further investigation outside the scope of this contract.~~ The contractor may proceed with the backfilling of the excavation with stone to groundwater and clean fill to grade as required in the above referenced contract specification.

Regards,


Mr. Dinker Desai
Environmental Engineer
Directorate of Public Works

CC: UST file copy

TVS
UTILITY MARKING REQUEST

Request marking of circled utility lines in the area indicated below.

NJ Nat. Gas Co.	Post Telephone
NJ Bell	Post water/sewer
NJ American Water Co.	Post Electric
JCP&L	Co. Sewage Auth.
Cable TV Co.	

COUNTY: Monmouth

TOWNSHIP: TINTON FALLS (See municipality list)

TOWN: Fort Monmouth

BUILDING NUMBER: 2236

STREET ADDRESS: 18+20 HEMPHILL RD

NEAREST CROSS STREET: HOPE RD, GUAM LANE

LOCATION OF EXCAVATION: ~~FRONT~~ BUILDING FRONT
(e.g. street, sidewalk, etc.)

DATE OF EXCAVATION: 11-2-99 0800

DEPTH OF EXCAVATION: 10 FT. MAX.

COMPANY NAME: TVS

COMPANY ADDRESS: P.O. Box 60
Ft. Monmouth, NJ 07703

S.O./(U.J.O.) NUMBER: 100004

NAME OF REQUESTOR: FRANK ACCORSI

DATE OF REQUEST: 10-26-99

NAME OF CALLER: _____

DATE OF CALL: _____

MARKING NUMBER: 993000417

Approval for emergency digging without marking:

UNDERGROUND STORAGE TANK REMOVAL
(550 G.)

**US ARMY, FORT MONMOUTH
DAILY UST CLOSURE LOG**

BLDG #: 2236 REG.#: 81515 - 6
 DATE: 11-16-99 TOA: _____ TOD: _____
 CLOSURE TECH: FRANK ACCORSI NJDEP CERT.#: 0010042
 PERSONNEL: FRANK ACCORSI, ED CRAWLEY

ACTIVITY	YES / NO
THE TECHNICIAN (CLOSURE CERT.) WAS ON-SITE DURING ALL CLOSURE RELATED ACTIVITIES	Y
THE SSE WAS ON-SITE DURING UST REMOVAL AND SITE SCREENING AND SAMPLING ACTIVITIES	Y
ALL ON-SITE PERSONNEL HAVE CURRENT TRAINING IAW ALL SAFETY REQ. (E.G. 29CFR)	Y
ALL UTILITIES WERE MARKED OUT PRIOR TO ANY EXCAVATION (VISUAL CONFIRM. <input checked="" type="checkbox"/> YES/NO)	Y
HAND EXCAVATION WAS DONE WHEN EXCAVATING WITHIN 4 FT OF ANY UTILITIES	Y
ALL UST PIPING WAS BLOWN BACK AND DRAINED PRIOR TO ANY EXCAVATION WITH BACKHOE	Y
ALL UST PIPING WAS REMOVED PRIOR TO UST EXCAVATION	Y
A CONFINED ENTRY PERMIT WAS COMPLETED AND POSTED ON-SITE BY THE CONTRACTOR	NA
THE UST WAS CLEANED AND NO RESIDUAL LIQUIDS WERE LEFT IN THE TANK	N
THE UST WAS PLACED ONTO PLASTIC, SCRAPED OFF, INSPECTED FOR HOLES AND PHOTOGRAPHED	Y
<u>0</u> DRUMS OF WASTE WERE GENERATED AT THIS SITE TODAY (ID CARDS COMPLETED)	Y
<u>0</u> DRUMS OF WASTE WERE TRANSPORTED TO THE (MP, CW, EV) HWSA	Y
<u>0</u> GALLONS OF _____ WASTE WERE REMOVED (MANIFEST#: _____)	Y
<u>0</u> CUBIC YARDS OF PETROL. CONT. SOIL WERE EXCAVATED+TRANS TO (T-80, 2624)	Y
THE DPW WAS NOTIFIED OF ANY DISCHARGE TO THE ENVIRONMENT. (WHO) _____	NA
ALL PETROL. CONT. SOILS WERE SECURED FROM THE WEATHER BY CLOSE OF BUSINESS TODAY	NA
THE DPW AUTHORIZED BACKFILLING THE EXCAVATION. SSE INITIAL REQUIRED: _____	Y
THE UST WAS TRANSPORTED TO <u>166 YARD</u> FOR DISPOSAL (ATTACH SCRAP TICKET)	Y
ADDITIONAL NOTES WERE TAKEN AND RECORDED ON THE BACK OF THIS FORM	N
THE FOLLOWING DOCUMENTS WERE GIVEN TO THE SSE TODAY: (CIRCLE EACH OR ADD ITEMS) _____ SCRAP TICKET, CSE PERMIT, ACCIDENT REPORT, _____	N

CHECK ALL BOXES, LEAVE NO BLANKS

I certify under penalty of law that tank decommissioning activities were performed in compliance with N.J.A.C. 7:14B-9.2(b)3. I am aware that there are significant penalties for submitting false, inaccurate, or incomplete information, including fines and/or imprisonment.

CLOSURE TECH (PRINT NAME): FRANK ACCORSI
 SIGNATURE: Frank Accorsi DATE: 11-16-99

US ARMY, SELFM-PW-EV

DAILY UST SUBSURFACE REMOVAL LOG

BLDG.#: 2236 REG.#: 81515 - 6
 DATE: 11-16-99 TOA: _____ TOD: _____
 SSE: FRANK ACCORSI NJDEP CERT.#: 0010042

REMOVAL CONTRACTOR: TVS Inc. PWS-007
 CLOSURE SUPERVISOR: FRANK ACCORSI NJDEP CERT.#: 0010042
 WEATHER: SUNNY, WINDY 40'S

ACTIVITY	YES / NO
THE TECHNICIAN (CLOSURE CERT.) WAS ON-SITE DURING ALL CLOSURE RELATED ACTIVITIES	Y
THE SSE WAS ON-SITE DURING UST REMOVAL AND SITE SCREENING AND SAMPLING ACTIVITIES	Y
ALL ON-SITE PERSONNEL HAD TRAINING IAW ALL SAFETY REQUIREMENTS (E.G. 29CFR)	Y
A CONFINED ENTRY PERMIT WAS COMPLETED AND POSTED ON-SITE BY THE CONTRACTOR	NA
THE UST WAS PLACED ONTO PLASTIC, SCRAPED OFF, INSPECTED FOR HOLES AND PHOTOGRAPHED	Y
A DISCHARGE WAS REPORTED BY THE DPW TO THE NJDEP (609-292-7172), CASE# _____	NA
PHOTOS HAVE UST#, BLDG. #, DATE, TIME, NAME OF SSE AND DESCR. WRITTEN ON BACK	Y
GROUNDWATER WAS ^{NOT} ENCOUNTERED AT _____ FEET BG, A SHEEN (WAS/WAS NOT) OBSERVED ON GW	NA
IF OVA WAS USED: WAS IT CAL. AND FOUND TO BE OPERATIONAL (cal. data on COC)	Y
IF SAMPLES WERE TAKEN: COC, SCALED SITE MAP (VERT. SOIL HORIZONS AND PLOT PLAN)	Y
ALL SAMPLE COLLECTION ACTIVITIES WERE AS DESCRIBED IN THE NJDEP FSPM, 1992	Y
ALL SAMPLING WAS BIASED TOWARD HIGHEST OVA/FID RECORDED SITES IAW 7:26E-3.6 et seq.	Y
ALL PETROL. CONT. SOILS WERE SECURED FROM THE WEATHER BY CLOSE OF BUSINESS TODAY	NA
THE DPW SSE AUTHORIZED BACKFILLING THE EXCAVATION (STONE TO 1" ABOVE GROUNDWATER) AND A BACKFILL AUTH. LTR. IS ATTACHED	Y
ALL ENVIRONMENTAL SAMPLE POINTS WERE GPS AND LOGGED	Y
ADDITIONAL NOTES WERE TAKEN AND ARE RECORDED ON THE BACK OF THIS FORM	Y
THE FOLLOWING DOCUMENTS WERE ADDED TO THE PROJECT FOLDER TODAY: (CIRCLE EACH) SCRAP TICKET, CSE PERMIT, ACCIDENT REPORT, HAZ. WASTE MANIFEST, <u>DAILY UST CLOSURE LOG</u> , <u>SCALED SITE MAP (SAMPLING)</u> , SRF-CLOSURE, CHAIN OF CUSTODY, SOIL ANALYTICAL RESULTS, CLEAN FILL TICKETS (IN YDS ³), PHOTOGRAPHS (UST, EXCAVATION, SAMPLING POINTS)	

CHECK ALL BOXES, LEAVE NO BLANKS

I certify under penalty of law that tank decommissioning activities were performed in compliance with N.J.A.C. 7:14B-9.2(b)3 and 7:26 et seq.. I am aware that there are significant penalties for submitting false, inaccurate, or incomplete information, including fines and/or imprisonment.

Closure Tech (print Name): FRANK ACCORSI Date: 11-16-99

SIGNATURE: Frank Accorsi

New Jersey One Call System

SEQUENCE NUMBER 0003

CDC = FOM

Transmit: Date: 10/27/99 At: 0953

*** R O U T I N E

*** Request No.: 993000417

Operators Notified:

CC4=/COMCAS-MNMOUTH / NJN=/NJNG-UTILIQUEST/ NJA=/NJ AMER WTR /
GP9=/GPU ENERGY-CLS / BAN=/BELL ATL NJ-CLS/ FOM=/FORT MONMOUTH /

Location Information:

County: MONMOUTH Municipality: TINTON FALLS
Subdivision/Community: FORT MONMOUTH
Street: 18 - 20 HEMPHILL RD
Nearest Intersection: HOPE RD
Other Intersection: GUAM LN
Type of Work : REMOVE UST

DEPTH: 10FT

Extent of Work: ENTIRE FRONT

Location Reference:

FRONT-

Start Date/Time: 11/02/99 At 0800

Remarks:

EXPIRATION DATE 12/13/99

1 BLDG 2 UNITS BLG 2236

Working For: TVS
Address: PO BOX 60
City: FORT MONMOUTH 07703
Phone: 732-532-6955
Contact: EILEEN MAIAR

Title:

Excavator Information:

Caller: EILEEN MAIAR
Phone: 732-532-6955

Title: WORK CNTRL

Excavator: TVS
Address: PO BOX 60
City: FORT MONMOUTH, NJ 07703
Phone: 732-532-6955
Contact: EILEEN MAIER
Phone: 732-532-6955
Cellular:

Fax: 732-542-1107
Title: WORK CNTRL
Best Time: 0800-1600

Alternate Field Contact:

Name: FRANK ACCORSCK
Phone: 732-532-2577
Cellular:

Title: SUBSRFC EV
Fax:
Best Time: 0800-1600

End Request

Acc

Report of Analysis
 U.S. Army, Fort Monmouth Environmental Laboratory
 NJDEP Certification # 13461

Client : U.S. Army
 DPW. SELFM-PW-EV
 Bldg. 173
 Ft. Monmouth, NJ 07703

Lab. ID # : 4951
Date Rec'd: 16-Nov-99
Analysis Start: 17-Nov-99
Analysis Complete: 17-Nov-99

Analysis: OQA-QAM-025
Matrix: Soil
Analyst: B.Patel
Inst. ID. GC TPHC INST. #1
Column Type RTX 5
Ext. Meth: Shake

UST Reg. #: 81515-6
Closure #:
DICAR #:
Injection Volume 1 ul
Column ID 0.32 mm
Location #: Bldg. 2236

Sample	Field ID	Dilution Factor	Weight (g)	% Solid	MDL (mg/kg)	TPHC Result (mg/kg)
4951.01	2236-A	1.00	15.06	82.26	190	ND
4951.02	2236-B	1.00	15.27	88.47	174	ND
4951.03	2236-C	1.00	15.97	84.12	175	ND
4951.04	2236-D Duplicate	1.00	15.38	81.81	187	ND
METHOD BLANK	TBLK284	1.00	15.00	100.00	157	ND

ND = Not Detected
 MDL = Method Detection Limit


 Daniel K. Wright
 Laboratory Director



Fort Monmouth Environmental Testing Laboratory

Bldg. 173, SELFM-PW-EV, Fort Monmouth, NJ 07703
 Tel (732)532-4359 Fax (732)532-6263 EMail: appleby@mail1.monmouth.army.mil
 NJDEP Certification #13461

Chain of Custody Record

Customer: Dinker Desai				Project No: 100004			Analysis Parameters				Comments:	
Phone #: X21475				Location: BLDG. 2236			TPHC	% SOLIDS	VOA+10	VOA ID #	PID Reading	* = Samples Kept <4°C
() DERA (X) OMA UST Assessment				UST# 81515-6								Remarks / Preservation Method
Samplers Name / Company : Frank Accorsi/TVS						Sample #						
Lab Sample I.D.	Sample Location	Date	Time	Type	bottles							
4901 01	2236-A WEST END, 7-7.5 FT	11-16-99	1400	SOIL	2	X	X	X	966	0	ICE	
02	2236-B EAST END, 7-7.5 FT		1415		2	X	X	X	967	0		
03	2236-C, PIPING, 1.5-2 FT		1430		2	X	X	X	968	0		
04	2236-D, DUPLICATE		1400		2	X	X	X	969	0		
05	TRIP BLANK		-	AQ.	1			X	992	-		
OVM sn#580U-64455.343 was calibrated with zero air & w/ 245 ppm Isobutylene read 247 ppm. 1300 11-19-99 FA (time/date & initial)												
Relinquished by (signature): <i>Frank Accorsi</i>		Date/Time: 11-19-99 1540		Received by (signature): <i>[Signature]</i>		Relinquished by (signature):		Date/Time:				
Relinquished by (signature):		Date/Time:		Received by (signature):		Relinquished by (signature):		Date/Time:				
Report Type: () Full, () Reduced, (X) Standard, () Screen / non-certified, () EDD						Remarks: Dedicated Sampling Tools Used						
Turnaround time: () Standard 2 wks. (X) Rush Days, () ASAP Verbal Hrs.						All sample points have been GPS? () YES () NO () NA						

SAMPLE RECEIPT FORM

Date Received: 11-16-99

Lab Project ID#: 4951

Site/Project Name: Bldg 2236

Cooler Temp (°C): 4.0

Received By: J. Verquwa
(print name)

Sign: [Signature]

Check the appropriate answer

- | | | | |
|---|---|-----------------------------|--|
| 1. Did the samples come in a cooler? | <input checked="" type="checkbox"/> yes | <input type="checkbox"/> no | <input type="checkbox"/> NA |
| 2. Were the chain of custody papers filled out correctly and legibly? | <input checked="" type="checkbox"/> yes | <input type="checkbox"/> no | |
| 3. Did you sign the chain of custody in the appropriate place? | <input checked="" type="checkbox"/> yes | <input type="checkbox"/> no | |
| 4. Did all the labels agree with the chain of custody and in good condition? | <input checked="" type="checkbox"/> yes | <input type="checkbox"/> no | |
| 5. Were the correct containers and/or preservatives used for the tests indicated? | <input checked="" type="checkbox"/> yes | <input type="checkbox"/> no | |
| 6. Was a sufficient amount of sample sent for the tests indicated? | <input checked="" type="checkbox"/> yes | <input type="checkbox"/> no | |
| 7. Were bubbles absent from aqueous VOC sample containers? | <input type="checkbox"/> yes | <input type="checkbox"/> no | <input checked="" type="checkbox"/> NA |
| 8. Were samples received on ice? | <input type="checkbox"/> yes | <input type="checkbox"/> no | |

Fill out the following table for each sample bottle

Sample ID	pH	Preservative	Sample ID	pH	Preservative

Comments: _____

RECEIVED
 NOV 17 1999
 ENVIRONMENTAL
 LABORATORY
 1000 ...
 ...

FORT MONMOUTH ENVIRONMENTAL TESTING LABORATORY

DIRECTORATE OF PUBLIC WORKS

PHONE: (732) 532-6263 FAX: (732) 532-6263

TESTS: METALS - ORGANICS - FIELD SAMPLING

CERTIFICATIONS: NJDEP #13461, NYSDOH #11699

ANALYTICAL DATA REPORT Fort Monmouth Environmental Laboratory ENVIRONMENTAL DIVISION Fort Monmouth, New Jersey PROJECT: IJO#100004

Field Sample Location	Laboratory Sample ID#	Matrix	Date and Time of Collection	Date Received
2236-A West End 7-7.9'	4951.01	Soil	16-Nov-99 14:00	11/16/99
2236-B East End 7-7.5'	4951.02	Soil	16-Nov-99 14:15	11/16/99
2236-C Piping 1.5-2'	4951.03	Soil	16-Nov-99 14:30	11/16/99
2236-D Duplicate	4951.04	Soil	16-Nov-99 14:00	11/16/99
Top Blank	4951.05	Methanol	16-Nov-99	11/16/99

FORT MONMOUTH ENVIRONMENTAL LAB
TPHC, %SOLIDS

ENCLOSURE:
CHAIN OF CUSTODY
RESULTS


12-8-99
Daniel Wright/Date
Laboratory Director

PORT WASHINGTON

Table of Contents

Section	Pages
Method Summary	1
Conformance/Non-Conformance	2
Chain of Custody	3
Results Summary	4
Initial Calibration Summary	5-6
Continuing Calibration Summary	7
Surrogate Results Summary	8
MS/MSD Results Summary	9
Blank Spike Summary	10
Raw Sample Data	11-20
Laboratory Deliverable Checklist	21
Laboratory Authentication Statement	22

Method Summary

NJDEP Method OQA-QAM-025-10/97

Gas Chromatographic Determination of Total Petroleum Hydrocarbons in Soil

Fifteen grams (15g)(wet weight) of a soil sample is added to a 125 mL acid cleaned, solvent rinsed, capped Erlenmeyer flask. 15g anhydrous sodium sulfate is added to dry sample. Surrogate standard spiking solution is then added to the flask.

Twenty five milliliters(25mL) Methylene Chloride is added to the flask and it is secured on a orbital shaker table. The agitation rate is set to 400rpm and the sample is shaken for 30 minutes. The flask is the removed from the table and the particulate matter is allowed to settle. The extract is transferred to a Teflon capped vial. A second 25mL of Methylene Chloride is added to the flask and shaken for an additional 30 minutes. The flask is again removed and allowed to settle. The extracts are combined in the vial then transferred to a 1mL autosampler vial.

The extract is then injected directly into a GC-FID for analysis. The sample is analyzed for petroleum hydrocarbons covering a range of C8-C42 including pristane and phytane. Total Petroleum Hydrocarbon concentration is determined by integrating between 5 minutes and 22 minutes. The baseline is established by starting the integration after the end of the solvent peak and stopping after the last peak.

The final concentration of Total Petroleum Hydrocarbons is calculated using percent solid, sample weight and concentration.

000001

TPHC Conformance/Non-conformance Summary Report

Indicate
Yes, No, N/A

1. **Method Detection Limits provided.**
2. **Method Blank Contamination – If yes, list the sample and the corresponding concentrations in each blank.**

3. **Matrix Spike Results Summary Meet Criteria**
(If not met, list the sample and corresponding recovery which falls outside the acceptable range).

4. **Duplicate Results Summary Meet Criteria**
(If not met, list the sample and corresponding recovery which falls outside the acceptable range).

5. **IR Spectra submitted for standards, blanks and samples.**
6. **Chromatograms submitted for standards, blanks and samples if GC fingerprinting was conducted.**
7. **Analysis holding time met.**
(If not met, list number of days exceeded for each sample).

YES

NO

YES

YES

NA

YES

YES

Additional comments: _____



Laboratory Manager

12-8-99
Date

001002

SAMPLE RECEIPT FORM

Date Received: 11-16-99

Lab Project ID#: 4951

Site/Project Name: Blk 2236

Cooler Temp (°C): 4.0

Received By: J. Verduwa
(print name)

Sign: [Signature]

Check the appropriate answer

- | | | | |
|---|---|-----------------------------|--|
| 1. Did the samples come in a cooler? | <input checked="" type="checkbox"/> yes | <input type="checkbox"/> no | <input type="checkbox"/> NA |
| 2. Were the chain of custody papers filled out correctly and legibly? | <input checked="" type="checkbox"/> yes | <input type="checkbox"/> no | |
| 3. Did you sign the chain of custody in the appropriate place? | <input checked="" type="checkbox"/> yes | <input type="checkbox"/> no | |
| 4. Did all the labels agree with the chain of custody and in good condition? | <input checked="" type="checkbox"/> yes | <input type="checkbox"/> no | |
| 5. Were the correct containers and/or preservatives used for the tests indicated? | <input checked="" type="checkbox"/> yes | <input type="checkbox"/> no | |
| 6. Was a sufficient amount of sample sent for the tests indicated? | <input checked="" type="checkbox"/> yes | <input type="checkbox"/> no | |
| 7. Were bubbles absent from aqueous VOC sample containers? | <input type="checkbox"/> yes | <input type="checkbox"/> no | <input checked="" type="checkbox"/> NA |
| 8. Were samples received on ice? | <input checked="" type="checkbox"/> yes | <input type="checkbox"/> no | |

Fill out the following table for each sample bottle

Sample ID	pH	Preservative	Sample ID	pH	Preservative

Comments:

Fort Monmouth Environmental Testing Laboratory

Bldg. 173, SELFM-PW-EV, Fort Monmouth, NJ 07703

Tel (732)532-4359 Fax (732)532-6263 EMail:appleby@mail1.monmouth.army.mil

NJDEP Certification #13461

Chain of Custody Record

Customer: Dinker Desai				Project No: 100004				Analysis Parameters				Comments:	
Phone #: X21475				Location: BLDG. 2236								* - Samples Kept <4°C	
<input type="checkbox"/> DERA <input checked="" type="checkbox"/> OMA UST Assessment				UST# 81515-6									
Samplers Name / Company: Frank Accorsi/TVS						Sample #							
Lab Sample ID:		Sample Location		Date	Time	Type	bottles	TPHC	% SOLIDS	VOA+10	VOA ID #	PID Reading	Remarks / Preservation Method
4901. 01A		2236-A WEST END, 7-7.5 FT		11-16-99	1400	SOIL	2	X	X	X	966	0	ICE
02		2236-B EAST END, 7-7.5 FT			1415		2	X	X	X	967	0	
03		2236-C PILING, 1.5-2 FT			1430		2	X	X	X	968	0	
04		2236-D DUPLICATE			1400		2	X	X	X	969	0	
05		TRIP BLANK			-	AQ	1			X	992	-	
OVM sn#580U-64453-343 was calibrated with zero air & w/ 245 ppm Isobutylene read 247 ppm. 1300 11-11-99 FH (time/date & initial)													
Relinquished by (signature): <i>Frank Accorsi</i>		Date/Time: 11-18-99 1540		Received by (signature): <i>[Signature]</i>		Relinquished by (signature):		Date/Time:					
Relinquished by (signature):		Date/Time:		Received by (signature):		Relinquished by (signature):		Date/Time:					
Report Type: <input type="checkbox"/> Full, <input type="checkbox"/> Reduced, <input checked="" type="checkbox"/> Standard, <input type="checkbox"/> Screen / non-certified, <input type="checkbox"/> EDD						Remarks: Dedicated Sampling Tools Used							
Turnaround time: <input type="checkbox"/> Standard 2 wks, <input checked="" type="checkbox"/> Rush 1 Days, <input type="checkbox"/> ASAP Verbal Hrs.						All sample points have been GPS? <input type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> NA							

000003

Report of Analysis
Army, Fort Monmouth Environmental Lab
NJDEP Certification # 13461

Client : U.S. Army
 DPW. SELFM-PW-EV
 Bldg. 173
 Ft. Monmouth, NJ 07703

Lab. ID # : 4951
Date Rec'd: 16-Nov-99
Analysis Start: 17-Nov-99
Analysis Complete: 17-Nov-99

Analysis: OQA-QAM-025
Matrix: Soil
Analyst: B.Patel
Inst. ID. GC TPHC INST. #1
Column Type RTX 5
Ext. Meth: Shake

UST Reg. #: 81515-6
Closure #:
DICAR #:
Injection Volume 1 ul
Column ID 0.32 mm
Location #: Bldg. 2236

Sample	Field ID	Dilution Factor	Weight (g)	% Solid	MDL (mg/kg)	TPHC Result (mg/kg)
4951.01	2236-A	1.00	15.06	82.26	190	ND
4951.02	2236-B	1.00	15.27	88.47	174	ND
4951.03	2236-C	1.00	15.97	84.12	175	ND
4951.04	2236-D Duplicate	1.00	15.38	81.81	187	ND
METHOD BLANK	TBLK284	1.00	15.00	100.00	157	ND

ND = Not Detected
 MDL = Method Detection Limit


 Daniel K. Wright
 Laboratory Director

Method : C:\HPCHEM\1\METHODS\TPH66.M (Chemstation Integrator)
 Title : TPHC Calibration 06/05/97 21 peaks
 Last Update : Wed Nov 17 14:48:28 1999

Calibration Files

100 =T009137.D 50 =T009138.D 20 =T009139.D
 10 =T009140.D 5 =T009141.D

Compound	100	50	20	10	5	Avg	%RSD
1) tC C8	2.564	2.455	2.647	2.599	2.646	2.582	E4 3.07
2) tC C10	2.605	2.600	2.721	2.834	2.715	2.695	E4 3.60
3) TC C12	2.594	2.590	2.710	2.817	2.833	2.709	E4 4.30
4) tC C14	2.574	2.561	2.696	2.793	2.875	2.700	E4 5.06
5) tC C16	2.583	2.576	2.713	2.829	2.971	2.734	E4 6.16
6) tC C18	2.699	2.599	2.963	2.817	3.006	2.817	E4 6.11
7) tC C20	2.712	2.706	2.838	2.973	3.094	2.865	E4 5.88
8) tC C22	2.754	2.748	2.898	3.040	3.183	2.925	E4 6.42
9) tC C24	2.787	2.778	2.932	3.069	3.207	2.955	E4 6.26
10) tC C26	2.752	2.741	2.899	3.051	3.259	2.940	E4 7.43
11) tC C28	2.742	2.727	2.865	2.982	3.103	2.884	E4 5.55
12) tC C30	2.826	2.804	2.913	3.050	3.153	2.949	E4 5.07
13) tC C32	2.730	2.698	2.755	2.833	2.881	2.779	E4 2.73
14) tC C34	2.709	2.724	2.786	2.839	3.016	2.815	E4 4.39
15) tC C36	2.288	2.331	2.386	2.407	2.550	2.392	E4 4.17
16) tC C38	2.040	2.295	2.361	2.436	2.660	2.358	E4 9.53
17) tC C40	1.509	1.830	1.857	1.896	2.378	1.894	E4 16.43
18) tC c42	1.390	1.737	1.749	1.808	2.407	1.818	E4 20.23
19) TC Pristane	2.788	2.686	2.832	2.995	3.198	2.900	E4 6.91
20) TC Phytane	2.764	2.647	2.881	3.053	3.274	2.924	E4 8.43
21) sC o-terphenyl	3.025	3.001	3.183	3.348	3.491	3.209	E4 6.54
22) tC TPHC - total	2.999	3.013	3.157	3.729	4.416	3.463	E4 17.63

Evaluate Continuing Calibration Report

Data File : C:\HPCHEM\1\DATA\91117\T009152.D
 Acq On : 17 Nov 1999 8:26 pm
 Sample : Tstd050
 Misc :
 IntFile : TPHCINT.E

Via 26
 Operator: Skelton
 Inst : GC/MS Ins
 Multiplr: 1.00

Method : C:\HPCHEM\1\METHODS\TPH66.M (Chemstation Integrator)
 Title : TPHC Calibration 06/05/97 21 peaks
 Last Update : Wed Nov 17 14:48:28 1999
 Response via : Multiple Level Calibration

Min. RRF : 0.000 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
 Max. RRF Dev : 15% Max. Rel. Area : 200%

Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)
1 tC C8	25.823	24.878 E3	3.7	101	-0.03
2 tC C10	26.950	25.871 E3	4.0	100	0.00
3 TC C12	27.089	25.572 E3	5.6	99	0.00
4 tC C14	26.999	25.274 E3	6.4	99	0.00
5 tC C16	27.344	25.243 E3	7.7	98	0.00
6 tC C18	28.171	26.411 E3	6.2	102	0.00
7 tC C20	28.647	26.060 E3	9.0	96	0.00
8 tC C22	29.246	26.723 E3	8.6	97	0.00
9 tC C24	29.548	26.990 E3	8.7	97	0.00
10 tC C26	29.402	26.584 E3	9.6	97	0.00
11 tC C28	28.837	26.450 E3	8.3	97	0.00
12 tC C30	29.493	27.161 E3	7.9	97	0.00
13 tC C32	27.794	26.330 E3	5.3	98	0.00
14 tC C34	28.148	26.311 E3	6.5	97	0.00
15 tC C36	23.924	22.781 E3	4.8	98	0.00
16 tC C38	23.584	21.615 E3	8.3	94	0.00
17 tC C40	18.939	16.977 E3	10.4	93	0.00
18 tC c42	18.180	16.086 E3	11.5	93	0.00
19 TC Pristane	28.998	27.338 E3	5.7	102	0.00
20 TC Phytane	29.238	26.751 E3	8.5	101	0.00
21 sC o-terphenyl	32.093	29.699 E3	7.5	99	0.00
22 tC TPHC - total	34.629	30.200 E3	12.8	100	0.62#

Evaluate Continuing Calibration Report

Data File : C:\HPCHEM\1\DAI 91117\T009165.D
 Acq On : 18 Nov 1999 3:50 am
 Sample : Tstd050
 Misc :
 IntFile : TPHCINT.E

Via 29
 Operator: Skelton
 Inst : GC/MS Ins
 Multiplr: 1.00

Method : C:\HPCHEM\1\METHODS\TPH66.M (Chemstation Integrator)
 Title : TPHC Calibration 06/05/97 21 peaks
 Last Update : Wed Nov 17 14:48:28 1999
 Response via : Multiple Level Calibration

Min. RRF : 0.000 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
 Max. RRF Dev : 15% Max. Rel. Area : 200%

Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)
1 tC C8	25.823	25.198 E3	2.4	103	-0.03
2 tC C10	26.950	26.272 E3	2.5	101	0.00
3 TC C12	27.089	25.732 E3	5.0	99	0.00
4 tC C14	26.999	25.146 E3	6.9	98	0.00
5 tC C16	27.344	24.959 E3	8.7	97	0.00
6 tC C18	28.171	26.425 E3	6.2	102	0.00
7 tC C20	28.647	25.570 E3	10.7	94	0.00
8 tC C22	29.246	25.763 E3	11.9	94	0.00
9 tC C24	29.548	25.144 E3	14.9	91	0.00
10 tC C26	29.402	23.803 E3	19.0	87	0.00
11 tC C28	28.837	23.048 E3	20.1	85	0.00
12 tC C30	29.493	23.530 E3	20.2	84	0.00
13 tC C32	27.794	22.846 E3	17.8	85	0.00
14 tC C34	28.148	22.971 E3	18.4	84	0.00
15 tC C36	23.924	19.232 E3	19.6	83	0.00
16 tC C38	23.584	16.707 E3	29.2#	73	0.00
17 tC C40	18.939	11.856 E3	37.4#	65	0.00
18 tC c42	18.180	10.085 E3	44.5#	58	-0.01
19 TC Pristane	28.998	26.347 E3	9.1	98	0.00
20 TC Phytane	29.238	25.338 E3	13.3	96	0.00
21 sC o-terphenyl	32.093	29.324 E3	8.6	98	0.00
22 tC TPHC - total	34.629	32.752 E3	5.4	109	0.61#

Surrogate Recovery Report
 Army, Fort Monmouth Environmental Labo. y
 NJDEP Certification # 13461

Client : U.S. Army **Lab. ID # :** 4951
 DPW. SELFM-PW-EV **Date Rec'd:** 16-Nov-99
 Bldg. 173 **Analysis Start:** 17-Nov-99
 Ft. Monmouth, NJ 07703 **Analysis Complete:** 17-Nov-99

Analysis: OQA-QAM-025 **UST Reg. #:**
Matrix: Soil **Closure #:**
Analyst: B.Patel **DICAR #:**
Inst. ID. GC TPHC INST. #1 **Injection Volume** 1 ul
Column Type RTX 5 **Column ID** 0.32 mm
Ext. Meth: Shake **Location #:** Bldg. 2236

Sample			Surrogate Added (ppm)	Amount Recovered (ppm)	Percent Recovery
4951.01			10.00	10.05	100.48
4951.02			10.00	9.73	97.30
4951.03			10.00	9.97	99.66
4951.04			10.00	9.80	97.98
METHOD BLANK	TBLK284		10.00	9.81	98.10

Surrogate Added : o-Terphenyl

Matrix Spike / Duplicate Recovery Report
 Army, Fort Monmouth Environmental Laboratory
 NJDEP Certification # 13461

Client :	U.S. Army	Lab. ID # :	4951
	DPW. SELFM-PW-EV	Date Rec'd:	16-Nov-99
	Bldg. 173	Analysis Start:	17-Nov-99
	Ft. Monmouth, NJ 07703	Analysis Complete:	17-Nov-99
Analysis:	OQA-QAM-025	UST Reg. #:	
Matrix:	Soil	Closure #:	
Analyst:	B.Patel	DICAR #:	
Inst. ID:	GC TPHC INST. #1	Injection Volume	1 ul
Column Type	RTX 5	Column ID	0.32 mm
Ext. Meth:	Shake	Location #:	Bldg. 2236

Sample	Spike Amount Added (ppm)	Sample Amount (ppm)	Matrix Spike Amount (ppm)	Percent Recovery	QC Limits %
4951.01MS	1000	0.00	829.89	82.99	75-125
4951.01MSD	1000	0.00	880.59	88.06	75-125

RPD	5.93	20.00
-----	------	-------

Quality Control Check Standard Summary
 U.S. Army, Fort Monmouth Environmental Laboratory
 NJDEP Certification # 13461

Client:	U.S. Army	Lab. ID #:	4951
	DPW. SELFM-PW-EV	Date Rec'd:	16-Nov-99
	Bldg. 173	Analysis Start:	17-Nov-99
	Ft. Monmouth, NJ 07703	Analysis Complete:	17-Nov-99
Analysis:	OQA-QAM-025	UST Reg. #:	
Matrix:	Soil	Closure #:	
Analyst:	B.Patel	DICAR #:	
Inst. ID.	GC TPHC INST. #1	Injection Volume	1 ul
Column Type	RTX 5	Column ID	0.32 mm
Ext. Meth:	Shake	Location #:	Bldg. 2236

Sample	Date Extracted	Spike Amount Added (ppm)	Matrix Spike Amount (ppm)	Percent Recovery	QC Limits %
Blank Spike	17-Nov-99	1000	789.27	78.93	75-125

Data File : C:\HPCHEM\1\LA\991117\T009146.D 1: 10
 Acq On : 17 Nov 1999 5:00 pm Operator: Skelton
 Sample : Tblk284s Inst : GC/MS Ins
 Misc : Multiplr: 1.00
 IntFile : TPHCINT.E
 Quant Time: Nov 18 8:37 1999 Quant Results File: TPH66.RES

Quant Method : C:\HPCHEM\1\METHODS\TPH66.M (Chemstation Integrator)
 Title : TPHC Calibration 06/05/97 21 peaks
 Last Update : Wed Nov 17 14:48:28 1999
 Response via : Initial Calibration
 DataAcq Meth : TPH66.M

Volume Inj. : 1 ul
 Signal Phase : HP-5
 Signal Info : 30m x 0.32mm

Compound	R.T.	Response	Conc Units
System Monitoring Compounds			
21) sC o-terphenyl	12.61	314833	9.810 mg/L
Spiked Amount	10.000 Range	8 - 13 Recovery	= 98.10%#
Target Compounds			


Quantitation Report

Data File : C:\HPCHEM\1\1A\991117\T009146.D
Acq On : 17 Nov 1999 5:00 pm
Sample : Tblk284s
Misc :
IntFile : TPHCINT.E
Quant Time: Nov 18 8:37 1999 Quant Results File: TPH66.RES

Al: 10
Operator: Skelton
Inst : GC/MS\Ins
Multiplr: 1.00

Quant Method : C:\HPCHEM\1\METHODS\TPH66.M (Chemstation Integrator)
Title : TPHC Calibration 06/05/97 21 peaks
Last Update : Wed Nov 17 14:48:28 1999
Response via : Multiple Level Calibration
DataAcq Meth : TPH66.M

Volume Inj. : 1 ul
Signal Phase : HP-5
Signal Info : 30m x 0.32mm



Data File : C:\HPCHEM\1\ A\991117\T009142.D L: 6
 Acq On : 17 Nov 1999 2:45 pm Operator: Skelton
 Sample : 4951.01s Inst : GC/MS Ins
 Misc : Multiplr: 1.00
 IntFile : TPHCINT.E
 Quant Time: Nov 17 15:11 1999 Quant Results File: TPH66.RES

Quant Method : C:\HPCHEM\1\METHODS\TPH66.M (Chemstation Integrator)
 Title : TPHC Calibration 06/05/97 21 peaks
 Last Update : Wed Nov 17 14:48:28 1999
 Response via : Initial Calibration
 DataAcq Meth : TPH66.M

Volume Inj. : 1 ul
 Signal Phase : HP-5
 Signal Info : 30m x 0.32mm

Compound	R.T.	Response	Conc Units
System Monitoring Compounds			
21) sC o-terphenyl	12.61	322476	10.048 mg/L
Spiked Amount 10.000 Range	8 - 13	Recovery	= 100.48%#
Target Compounds			
22) tC TPHC - total	12.61	1374957	39.706 mg/L m


000013

Quantitation Report

Data File : C:\HPCHEM\1\ A\991117\T009142.D 1: 6
Acq On : 17 Nov 1999 2:45 pm Operator: Skelton
Sample : 4951.01s Inst : GC/MS Ins
Misc : Multiplr: 1.00
IntFile : TPHCINT.E
Quant Time: Nov 17 15:11 1999 Quant Results File: TPH66.RES

Quant Method : C:\HPCHEM\1\METHODS\TPH66.M (Chemstation Integrator)
Title : TPHC Calibration 06/05/97 21 peaks
Last Update : Wed Nov 17 14:48:28 1999
Response via : Multiple Level Calibration
DataAcq Meth : TPH66.M

Volume Inj. : 1 ul
Signal Phase : HP-5
Signal Info : 30m x 0.32mm



Data File : C:\HPCHEM\1 A\991117\T009143.D 1: 7
 Acq On : 17 Nov 1999 3:19 pm Operator: Skelton
 Sample : 4951.02s Inst : GC/MS Ins
 Misc : Multiplr: 1.00
 IntFile : TPHCINT.E
 Quant Time: Nov 17 15:49 1999 Quant Results File: TPH66.RES

Quant Method : C:\HPCHEM\1\METHODS\TPH66.M (Chemstation Integrator)
 Title : TPHC Calibration 06/05/97 21 peaks
 Last Update : Wed Nov 17 14:48:28 1999
 Response via : Initial Calibration
 DataAcq Meth : TPH66.M

Volume Inj. : 1 ul
 Signal Phase : HP-5
 Signal Info : 30m x 0.32mm

Compound	R.T.	Response	Conc Units
System Monitoring Compounds			
21) sC o-terphenyl	12.61	312268	9.730 mg/L
Spiked Amount 10.000	Range 8 - 13	Recovery =	97.30%#
Target Compounds			
22) tC TPHC - total	12.61	1394200	40.261 mg/L m


Quantitation Report

Data File : C:\HPCHEM\1\ A\991117\T009143.D
Acq On : 17 Nov 1999 3:19 pm
Sample : 4951.02s
Misc :
IntFile : TPHCINT.E
Quant Time: Nov 17 15:49 1999 Quant Results File: TPH66.RES

1: 7
Operator: Skelton
Inst : GC/MS Ins
Multiplr: 1.00

Quant Method : C:\HPCHEM\1\METHODS\TPH66.M (Chemstation Integrator)
Title : TPHC Calibration 06/05/97 21 peaks
Last Update : Wed Nov 17 14:48:28 1999
Response via : Multiple Level Calibration
DataAcq Meth : TPH66.M

Volume Inj. : 1 ul
Signal Phase : HP-5
Signal Info : 30m x 0.32mm



Data File : C:\HPCHEM\1\ A\991117\T009144.D 1: 8
 Acq On : 17 Nov 1999 3:52 pm Operator: Skelton
 Sample : 4951.03s Inst : GC/MS Ins
 Misc : Multiplr: 1.00
 IntFile : TPHCINT.E
 Quant Time: Nov 17 16:24 1999 Quant Results File: TPH66.RES

Quant Method : C:\HPCHEM\1\METHODS\TPH66.M (Chemstation Integrator)
 Title : TPHC.Calibration 06/05/97 21 peaks
 Last Update : Wed Nov 17 14:48:28 1999
 Response via : Initial Calibration
 DataAcq Meth : TPH66.M

Volume Inj. : 1 ul
 Signal Phase : HP-5
 Signal Info : 30m x 0.32mm

Compound	R.T.	Response	Conc Units
----------	------	----------	------------

System Monitoring Compounds

21) sC o-terphenyl	12.61	319847	9.966 mg/L
Spiked Amount 10.000	Range 8 - 13	Recovery =	99.66%#

Target Compounds


Quantitation Report

Data File : C:\HPCHEM\1 A\991117\T009144.D
Acq On : 17 Nov 1999 3:52 pm
Sample : 4951.03s
Misc :
IntFile : TPHCINT.E
Quant Time: Nov 17 16:24 1999 Quant Results File: TPH66.RES

1: 8
Operator: Skelton
Inst : GC/MS Ins
Multiplr: 1.00

Quant Method : C:\HPCHEM\1\METHODS\TPH66.M (Chemstation Integrator)
Title : TPHC Calibration 06/05/97 21 peaks
Last Update : Wed Nov 17 14:48:28 1999
Response via : Multiple Level Calibration
DataAcq Meth : TPH66.M

Volume Inj. : 1 ul
Signal Phase : HP-5
Signal Info : 30m x 0.32mm



Data File : C:\HPCHEM\1\ 1A\991117\T009145.D
 Acq On : 17 Nov 1999 4:26 pm
 Sample : 4951.04s
 Misc :
 IntFile : TPHCINT.E
 Quant Time: Nov 18 8:37 1999 Quant Results File: TPH66.RES

al: 9
 Operator: Skelton
 Inst : GC/MS Ins
 Multiplr: 1.00

Quant Method : C:\HPCHEM\1\METHODS\TPH66.M (Chemstation Integrator)
 Title : TPHC Calibration 06/05/97 21 peaks
 Last Update : Wed Nov 17 14:48:28 1999
 Response via : Initial Calibration
 DataAcq Meth : TPH66.M
 Volume Inj. : 1 ul
 Signal Phase : HP-5
 Signal Info : 30m x 0.32mm

Compound	R.T.	Response	Conc. Units
System Monitoring Compounds			
21) sC o-terphenyl	12.61	314449	9.798 mg/L
Spiked Amount 10.000	Range 8 - 13	Recovery =	97.98%#
Target Compounds			


Quantitation Report

Data File : C:\HPCHEM\1\DATA\991117\T009145.D
Acq On : 17 Nov 1999 4:26 pm
Sample : 4951.04s
Misc :
IntFile : TPHCINT.E
Quant Time: Nov 18 8:37 1999 Quant Results File: TPH66.RES

1: 9
Operator: Skelton
Inst : GC/MS Ins
Multiplr: 1.00

Quant Method : C:\HPCHEM\1\METHODS\TPH66.M (Chemstation Integrator)
Title : TPHC Calibration 06/05/97 21 peaks
Last Update : Wed Nov 17 14:48:28 1999
Response via : Multiple Level Calibration
DataAcq Meth : TPH66.M

Volume Inj. : 1 ul
Signal Phase : HP-5
Signal Info : 30m x 0.32mm



LABORATORY DELIVERABLES CHECKLIST AND NON-CONFORMANCE SUMMARY

THIS FORM MUST BE COMPLETED BY THE LABORATORY OR ENVIRONMENTAL CONSULTANT AND ACCOMPANY ALL DATA SUBMISSIONS

The following Laboratory Deliverables checklist and Non-Conformance Summary shall be included in the data submission. All deviations from the accepted methodology and procedures, of performance values outside acceptable ranges shall be summarized in the Non-Conformance Summary. The Technical Requirements for Site Remediation, effective June 7, 1993, provides further details. The document shall be bound and paginated, contain a table of contents, and all pages shall be legible. Incomplete packages will be returned or held without review until the data package is completed.


It is recommended that the analytical results summary sheets listing all targeted and non-targeted compounds with the method detection limits, practical quantitation limits, and the laboratory and/or sample numbers be included in one section of the data package and in the main body of the report.

1. Cover page, Title Page listing Lab Certification #, facility name and address, & date of report submitted
2. Table of Contents submitted
3. Summary Sheets listing analytical results for all targeted and non-targeted compounds submitted
4. Document paginated and legible
5. Chain of Custody submitted
6. Samples submitted to lab within 48 hours of sample collection
7. Methodology Summary submitted
8. Laboratory Chronicle and Holding Time Check submitted
9. Results submitted on a dry weight basis
10. Method Detection Limits submitted
11. Lab certified by NJDEP for parameters of appropriate category of parameters or a member of the USEPA CLP

✓
✓
✓
✓
✓
✓
✓
✓
✓
✓
✓

Laboratory Manager or Environmental Consultant's Signature

Date 12/8/99



Laboratory Certification #13461

*Refer to NJAC 7:26E - Appendix A, Section IV - Reduced Data Deliverables - Non-USEPA/CLP Methods for further guidance.

Laboratory Authentication Statement

I certify under penalty of law, where applicable, that this laboratory meets the Laboratory Performance Standards and Quality Control requirements specified in N.J.A.C. 7:18 and 40 CFR Part 136 for Water and Wastewater Analyses and SW-846 for Solid Waste Analysis. I have personally examined the information contained in this report and to the best of my knowledge, I believe that the submitted information is true, accurate, complete and meets the above referenced standards where applicable. I am aware that there are significant penalties for purposefully submitting falsified information, including the possibility of a fine and imprisonment.



Daniel K. Wright
Laboratory Manager