



DEPARTMENT OF THE ARMY

HEADQUARTERS, U.S. ARMY GARRISON FORT MONMOUTH

FORT MONMOUTH, NEW JERSEY 07703-5101



August 26, 2009

From: Howard M. Syvarth, TVS Hydrogeologist
To: UST file
Subject: UST Closure Reports for Building 2240/Tank Registration #: 81515-10


Enclosed are the file review sheets for the closure of the Underground Storage Tank(s) (USTs) located at the above referenced location. After performing a file review to include submittals to NJDEP, I have determined that the tank closure and the subsequent report meet the minimum requirements established by NJDEP and as such are considered to be closed by both NJDEP and the Directorate of Public Works, US Army Garrison Fort Monmouth.

This document serves as the official site closure. All supporting documentation for the closure of this site can be found in the UST folder located in the library archive in Bldg. 173, Fort Monmouth, New Jersey.

Any questions regarding the information found in this or any other UST folder should be directed to:

Howard M. Syvarth
TECOM-Vinnell Services (TVS)
Staff Hydrogeologist, UST program
Directorate of Public Works, Ft. Monmouth, NJ
Email: Howard.M.Syvarth@us.army.mil

Sincerely,


Howard M. Syvarth
TVS Staff Hydrogeologist

Mr. Charles Appleby
Subsurface Evaluator NJDEP #9974
Environmental Protection Specialist
Directorate of Public Works

Fort Monmouth UST Status Summary Report

UST REGISTRATION INFORMATION SUMMARY

LOCATION: 2240 **NJDEP REG ID:** 81515 - 10
RESIDENTIAL? YES

UST CONSTRUCTION INFORMATION SUMMARY

SIZE (GALLONS): 550 **CONSTRUCTION:** FRP
PRODUCT: #2 FUEL OIL **YEAR INSTALLED:** 1985

UST REMOVAL/INVESTIGATION SUMMARY

REMOVAL DATE: 1/3/2000 **REMOVAL CONTRACTOR:** TVS

SRF SEND DATE: **TMS:**

DICAR NO. **LEAK DETECT:** N/A

REMEDIALTION COMMENTS: 11/08/94 SAI removed 118 gallons of oil; left 16 gallons of waste in tank. Residential UST with no DICAR and no contamination; no Closure Report required.

REGISTRATION COMMENTS:

SAS DONE: **CONSULTANT:** TVS

MW's NEEDED: 0 **MONITORING WELLS:** 0

SUB-SURFACE EVALUATOR: D. Desai

CURRENT UST STATUS

UST STATUS: Removed; Report Submitted/Not Nec. **CASE STATUS:** Case Closed

SUBMITTAL DATE: **APPROVAL DATE:**

Fort Monmouth Underground Storage Tank Assessment Questionnaire

Site Name: 2240 -

Is the UST Residential: YES

There is / are 1 UST(s) located at this site.

This NJDEP UST Registration # is: 81515 - 10 to _____

This UST was 550 Gallons in size, was made of FRP and contained #2 FUEL OIL.

The UST was installed in 1985 _____ and removed by TVS _____ on 1/3/2000 _____ . A

Standard Reporting Form was sent to the NJDEP on _____ . NJDEP Closure # _____

Subsurface Evaluator: D. Desai _____ NJDEP # _____

A Site Investigation Report was completed by TVS _____ and submitted to the NJDEP on _____

The Current Status is: *Removed; Report Submitted/Not Nec.*

The Revised Status as of _____ completed by _____ is:

The Current UST Database Comments are: *11/08/94 SAI removed 118 gallons of oil; left 16 gallons of waste in tank. Residential UST with no DICAR and no contamination; no Closure Report required.*

The Revised Comments as of 10/27/08 completed by Howard Sykes is:

NO NFA, non-leaking, nonregulated residential UST.

Database updated on _____ by _____

Remedial Phases: PA SI RI RAW CEA NFA

Project transferred to the Fort Monmouth Restoration Program

Project # FTMM- _____

CASE STATUS: *Case Closed*
NFA ISSUED:
File Review Date: 10/27/08
By: Howard Sykes

Fort Monmouth Underground Storage Tank Assessment Questionnaire

1. Has the property been or is the property currently the subject of any remediation with NJDEP oversight? [] Yes [X] No

If Yes, provide the following:

Case Number _____

Case Lead (US Army) _____

Case Manager (NJDEP) _____

Case Status Data base " Case Closed ", As of this date: _____

2. Was a Preliminary Assessment (PA) performed in accordance with N.J.A.C. 7: 26E-3.1? [] Yes [X] No

3. Were any Areas of Concern (AOCs) identified? [X] Yes [] No
If yes proceed to question 4. If no, proceed to Check List (page 8).

4. Were any potentially contaminated AOCs identified? [X] Yes [] No

List and describe all **potentially contaminated** AOCs.

UST Area [X] Underground Piping Area [X] Dispenser Area [] UST Fill Area [X]

5. List and describe all AOCs subject to the 7:26E Regulations.
UST Area [X] Underground Piping Area [X] Dispenser Area [] UST Fill Area [X]

6. Was a discharge of a hazardous substance, contaminant or pollutant identified? [] Yes [X] No

If so, was the discharge to: (check all that apply)

Soil [] Ground Water [] Surface Water [] Ecologically Sensitive Area []

Other [] (specify) _____

Fort Monmouth Underground Storage Tank Assessment Questionnaire

7. How was the discharge identified? (check all that apply)

Sample Analysis [] Olfactory [] Visual [] Record/ Loss of Product [] Field Analysis []
Other [] (specify) _____

8. What was the source of the discharge?

UST Area [] Underground Piping Area [] Dispenser Area [] UST Fill Area []

9. Were any of the following conditions present? (Check all that apply.)

Soil Staining [] Distressed or Dead Vegetation [] Product Entering Storm Sewer []
Product Entering Basement [] Off-site Migration [] Product Observed on Surface Water []
Other [] (specify) _____

10. Were samples collected in accordance with the provisions of N.J.A.C. 7:26E and the Department's applicable Field Sampling Procedures Manual?

Yes [] No

TPHC VOA+10 [] BN+15 [] lead [] PP+40 []

Other: _____

11. Were soil samples collected at the appropriate depth as per N.J.A.C. 7:26E

Yes [] No

12. Were samples biased toward the most contaminated areas using field instruments and/or visual and olfactory observations?

Yes [] No

How was this accomplished? _____

13. If only TPHC samples taken, were samples >1000mg/kg run for VOA+10?

[] Yes No

all samples were < 1,000 ppm

14. Was the vertical and horizontal extent of soil contamination delineated prior to remediation?

[] Yes No

Explain: _____

no discharge or release no remediation required

Fort Monmouth Underground Storage Tank Assessment Questionnaire

15. Fully describe the method of remediation?

Source Removal and Disposal Free Product removal by Vacuum Truck

Other: _____

16. If excavation was performed, what was the depth of the bottom of the excavation? ~ 7 feet.

17. What is the approximate depth to saturated zone (seasonally high water table)? _____ feet.

How was this determined? Observed Measurement Monitoring Well

Other: _____

18. Is the Site Tidally Impacted? Yes No

19. What is the percentage of silt/clay in the soil between the contaminant and the saturated zone?

_____. How was this determined? _____

 Not Available

20. Was ground water present in the excavation? Yes No

If yes, was there a sheen observed on ground water? Yes No

21. Are there any Public Supply Wells within 2,000 feet of confirmed soil contamination? Yes No

How was this determined? Well Search : _____

22. Was contaminated soil removed from the site? Yes No

How much soil was removed? _____ tons/cubic yards (circle one)

To what facility was the soil taken? _____

Date taken: _____

23. Were the analytical results for all soil post excavation/remediation samples below the Department's ~~June~~ Sept. 2008 residential soil cleanup criteria? Yes No

Fort Monmouth Underground Storage Tank Assessment Questionnaire

If No, describe in detail in Comments Page 6

22. Was this an investigation pertaining to a non-regulated heating oil tank? Yes No
Fort Monmouth Database : : YES
If yes, complete the following, If no go to 23
- Do on-site structures have a basement/crawl space? Yes No
 Was staining observed on the basement/crawl space walls or floor? Yes No NA
 Were petroleum odors observed in the basement/crawl space? Yes No NA
 Is a sump present in the basement/crawl space? Yes No NA
If yes, please indicate location on site map.
- Was water observed in the sump? Yes No NA
 Was a sheen observed on the water in sump? Yes No NA
 If there was no water in the sump was the base of the sump investigated for a petroleum discharge? Yes No NA
 If the sump was investigated, was a discharge observed? Yes No NA
23. Is a regulated underground storage tank the subject of the remediation? Yes No
If yes, complete the following, If no, go to 24
- Was a closure approval or 14 day notification obtained prior to the closure of the tank? Yes No
 List Closure Approval/Notification Numbers NJDEP Closure # _____
 Was the closure or any remediation performed by an individual and firm certified in closure and subsurface evaluation? Yes No
- Subsurface Evaluator: D. Desai** _____
 Individual certification number: _____
 Firm certification number: _____
- Was an Underground Storage Tank Facility Certification Questionnaire completed and submitted "delisting" the subject tanks? Yes No
24. Was a Baseline Ecological Evaluation conducted pursuant to N.J.A.C 7:26E? Yes No
 If No, was the BEE a regulatory requirement at the time? Yes NA
 (UST removed prior to 1997 or the UST is Residential?)
 If Yes, is there a contaminant of concern present? Yes No

Fort Monmouth Underground Storage Tank Assessment Questionnaire

Are there environmentally sensitive natural resources within or surrounding the property? Yes No

Are there potential contaminant migration pathways present? Yes No

Were potential ecological impacts identified? Yes No

Is a BEE planned to be completed for this site? Yes No

25. Was the site restored in accordance to N. J.A.C. 7:26E-6.4(b)? Yes No

26. Was the remedial investigation/action report prepared in accordance with N.J.A.C. 7:26E? Yes No

27. Remediation completed date: 1/3/00

28. Are there currently, or have there ever been, any Deed Notices or Declarations of Environmental Restriction pursuant to N.J.S.A. 58:10B-1 et seq. and N.J.A.C. 7:26E-1 et seq. for the Site? Yes No

If yes, Attach a copy of the Deed Notice or Declaration of Environmental Restriction.

29. Has NJDEP ever issued a no further action letter ("NFA") for any portion of the Site? Yes No

NFA ISSUED:

If Yes, in accordance with N.J.S.A. 58:10B-13(e), is there an order of magnitude difference between the currently applicable remediation standard or criterion and the contaminant level approved under such previously issued NFA? Yes No

31. Subcontractors employed during the investigation/remediation (list all):

Name/Address: TVS

Name/Address: TVS

Name/Address: _____

Name/Address: _____

Name/Address: _____

COMMENTS:

Fort Monmouth Underground Storage Tank Assessment
Questionnaire

Multiple horizontal lines for writing.

PRINT LEGIBLE.

Fort Monmouth Underground Storage Tank Assessment Questionnaire

Site Investigation - Remedial Investigation/Action Report Checklist: DATE: _____

- | | | | |
|--|---|--|--|
| • Soil Contamination currently exists on site | []Yes | <input checked="" type="checkbox"/> No | []NA |
| • GW Contamination currently exists on site | []Yes | <input checked="" type="checkbox"/> No | []NA |
| • Contaminated Soil Disposal Receipt (fully executed manifest) | []Yes | <input checked="" type="checkbox"/> No | []NA |
| • Tank Disposal Certificate | <input checked="" type="checkbox"/> Yes | []No | []NA |
| • Tank Contents Disposal Receipt (fully executed manifest) | []Yes | <input checked="" type="checkbox"/> No | <input checked="" type="checkbox"/> NA |
| • Fill was "certified clean" in accordance with N.J.A.C.7:26E-6.4 | []Yes | []No | <input checked="" type="checkbox"/> NA |
| • Scaled site map with AOCs and north arrow | []Yes | <input checked="" type="checkbox"/> No | []NA |
| • Sample Results Summary Tables (N.J.A.C.7:26E-4.8) | <input checked="" type="checkbox"/> Yes | []No | []NA |
| • Laboratory was certified to perform the required tests | <input checked="" type="checkbox"/> Yes | []No | []NA |
| • Chain of Custody forms submitted | <input checked="" type="checkbox"/> Yes | []No | []NA |
| • Signed laboratory deliverables checklist and Non-Conformance Summaries submitted | <input checked="" type="checkbox"/> Yes | []No | []NA |
| • Problems identified in the laboratory deliverables checklist and Non-Conformance summaries | <input checked="" type="checkbox"/> Yes | []No | []NA |
| • Holding times were met for all analyses | <input checked="" type="checkbox"/> Yes | []No | []NA |
| • MDLs below most stringent soil cleanup criteria | <input checked="" type="checkbox"/> Yes | []No | []NA |
| • Laboratory sample summary submitted | <input checked="" type="checkbox"/> Yes | []No | []NA |
| • QA/QC package (reduced deliverables) submitted | []Yes | []No | <input checked="" type="checkbox"/> NA |
| • VOC soil samples methanol preserved (sample weights included) | <input checked="" type="checkbox"/> Yes | []No | []NA |
| • Electronic data package (home heating oil tanks exempt) | []Yes | []No | <input checked="" type="checkbox"/> NA |
| • Well search submitted | []Yes | []No | <input checked="" type="checkbox"/> NA |
| • Baseline Environmental Evaluation (home heating oil tanks exempt) | []Yes | []No | <input checked="" type="checkbox"/> NA |
| • Closure approval notification enclosed | []Yes | []No | <input checked="" type="checkbox"/> NA |
| • No Further Action letter(s) enclosed | []Yes | []No | <input checked="" type="checkbox"/> NA |

US ARMY, SELFM-PW-EV

DAILY UST SUBSURFACE REMOVAL LOG

BLDG.#: 2240 REG.#: 81515 - 10
 DATE: 1-3-00 TOA: _____ TOD: _____
 SSE: FRANK ACCORSI NJDEP CERT.#: 0010042
 REMOVAL CONTRACTOR: TVS Inc. PWS-007
 CLOSURE SUPERVISOR: FRANK ACCORSI NJDEP CERT.#: 0010042
 WEATHER: PT. CLOUD, 50-60'S

ACTIVITY	YES / NO
THE TECHNICIAN (CLOSURE CERT.) WAS ON-SITE DURING ALL CLOSURE RELATED ACTIVITIES	Y
THE SSE WAS ON-SITE DURING UST REMOVAL AND SITE SCREENING AND SAMPLING ACTIVITIES	Y
ALL ON-SITE PERSONNEL HAD TRAINING IAW ALL SAFETY REQUIREMENTS (E.G. 29CFR)	Y
A CONFINED ENTRY PERMIT WAS COMPLETED AND POSTED ON-SITE BY THE CONTRACTOR	NA
THE UST WAS PLACED ONTO PLASTIC, SCRAPED OFF, INSPECTED FOR HOLES AND PHOTOGRAPHED	Y
A DISCHARGE WAS REPORTED BY THE DPW TO THE NJDEP (609-292-7172), CASE# _____	NA
PHOTOS HAVE UST#, BLDG. #, DATE, TIME, NAME OF SSE AND DESCR. WRITTEN ON BACK	Y
GROUNDWATER WAS ENCOUNTERED AT _____ FEET BG, A SHEEN (WAS/WAS NOT) OBSERVED ON GW	NA
IF OVA WAS USED: WAS IT CAL. AND FOUND TO BE OPERATIONAL. (cal. data on COC)	Y
IF SAMPLES WERE TAKEN: COC, SCALED SITE MAP (VERT. SOIL HORIZONS AND PLOT PLAN)	Y
ALL SAMPLE COLLECTION ACTIVITIES WERE AS DESCRIBED IN THE NJDEP FSPM, 1992	Y
ALL SAMPLING WAS BIASED TOWARD HIGHEST OVA/FID RECORDED SITES IAW 7:26E-3.6 et seq.	Y
ALL PETROL. CONT. SOILS WERE SECURED FROM THE WEATHER BY CLOSE OF BUSINESS TODAY	NA
THE DPW SSE AUTHORIZED BACKFILLING THE EXCAVATION (STONE TO 1" ABOVE GROUNDWATER) AND A BACKFILL AUTH. LTR. IS ATTACHED	Y
ALL ENVIRONMENTAL SAMPLE POINTS WERE GPS AND LOGGED	Y
ADDITIONAL NOTES WERE TAKEN AND ARE RECORDED ON THE BACK OF THIS FORM	N
THE FOLLOWING DOCUMENTS WERE ADDED TO THE PROJECT FOLDER TODAY: (CIRCLE EACH) SCRAP TICKET, CSE PERMIT, ACCIDENT REPORT, HAZ. WASTE MANIFEST, <u>DAILY UST CLOSURE LOG</u> , SCALED SITE MAP (SAMPLING), <u>SRP-CLOSURE</u> , <u>CHAIN OF CUSTODY</u> , <u>SOIL ANALYTICAL RESULTS</u> , CLEAN FILL TICKETS (IN YDS ³), PHOTOGRAPHS (UST, EXCAVATION, SAMPLING POINTS)	

CHECK ALL BOXES, LEAVE NO BLANKS

I certify under penalty of law that tank decommissioning activities were performed in compliance with N.J.A.C. 7:14B-9.2(b)3 and 7:26 et seq.. I am aware that there are significant penalties for submitting false, inaccurate, or incomplete information, including fines and/or imprisonment.

Closure Tech (print Name): FRANK ACCORSI Date: 1-3-00

SIGNATURE: Frank Accorsi

UNDERGROUND STORAGE TANK PROJECT REMOVAL/REMEDATION WORKSHEET

PROJECT SITE: <u>BLDG. 2240</u> <u>26/28 HEMPHILL RD</u>	DATE OF TANK REMOVAL: <u>1-3-00</u>	WORKSHEET PREPARED BY: <u>FRANK ACCORSI</u>
COMMENTS:	CONFINED SPACE ENTRY NOTIFICATIONS: <u>N/A</u> FT. MONMOUTH FIRE DEPARTMENT- QC/SAFETY OFFICE- WEATHER: <u>PT. CLOUD, 50-60'S</u>	
EVIDENCE OF A DISCHARGE: <u>NO</u>	CONDITION OF THE TANK/PIPING: <u>VERY GOOD - 550 G.</u> <u>SINGLE WALL FIBERGLASS</u> <u>PIPING: 2 x 5/8" COPPER</u> <u>(SUPPLY/RETURN); 2 IN. STEEL</u> <u>VENT PIPE.</u>	
TYPICAL SOIL PROFILE: <u>Brown med-fine SAND, little silt</u> <u>UST SURROUNDED BY PEA GRAVEL.</u>		
SITE INFORMATION: PRODUCT REMOVED FROM TANK- <u>~20 GAL.</u> SOLIDS (OIL SPILL DEBRIS)- APPROX. DEPTH TO GROUNDWATER- <u>NONE</u> DEPTH OF SOIL COVER- <u>2 FT 2 IN</u> TANK DIAMETER/LENGTH- <u>4 FT x 6 FT</u> DEPTH OF EXCAVATION- <u>7 FT.</u>	SOIL SAMPLING: DATE- <u>1-3-00</u> FIELD DUPLICATE = SAMPLE <u>2240 B (EAST END)</u> COMMENTS- <u>TPH w/CONTINGENT VOX10</u> <u>ANALYSIS.</u>	
SOIL SAMPLING: DATE- FIELD DUPLICATE = SAMPLE _____ COMMENTS-	SOIL SAMPLING: DATE- FIELD DUPLICATE = SAMPLE _____ COMMENTS-	

**US ARMY, FORT MONMOUTH
DAILY UST CLOSURE LOG**

BLDG.#: 2240 REG.#: 81575 -10
 DATE: 1-3-00 TOA: _____ TOD: _____
 CLOSURE TECH: FRANK ACCORSI NJDEP CER.#: 0010042
 PERSONNEL: ED CRAWLEY, MARK VETRE

ACTIVITY	YES / NO
THE TECHNICIAN (CLOSURE CERT.) WAS ON-SITE DURING ALL CLOSURE RELATED ACTIVITIES	Y
THE SSE WAS ON-SITE DURING UST REMOVAL AND SITE SCREENING AND SAMPLING ACTIVITIES	Y
ALL ON-SITE PERSONNEL HAVE CURRENT TRAINING IAW ALL SAFETY REQ. (E.G. 29CFR)	Y
ALL UTILITIES WERE MARKED OUT PRIOR TO ANY EXCAVATION (VISUAL CONFIRM. <u>YES</u> NO)	Y
HAND EXCAVATION WAS DONE WHEN EXCAVATING WITHIN 4 FT OF ANY UTILITIES	Y
ALL UST PIPING WAS BLOWN BACK AND DRAINED PRIOR TO ANY EXCAVATION WITH BACKHOE	Y
ALL UST PIPING WAS REMOVED PRIOR TO UST EXCAVATION	N
A CONFINED ENTRY PERMIT WAS COMPLETED AND POSTED ON-SITE BY THE CONTRACTOR	NA
THE UST WAS CLEANED AND NO RESIDUAL LIQUIDS WERE LEFT IN THE TANK	N
THE UST WAS PLACED ONTO PLASTIC, SCRAPED OFF, INSPECTED FOR HOLES AND PHOTOGRAPHED	Y
_____ DRUMS OF WASTE WERE GENERATED AT THIS SITE TODAY (ID CARDS COMPLETED)	NA
_____ DRUMS OF WASTE WERE TRANSPORTED TO THE (MP, CW, EV) HWSA	NA
_____ GALLONS OF _____ WASTE WERE REMOVED (MANIFEST#: _____)	NA
_____ CUBIC YARDS OF PETROL. (CONT. SOIL WERE EXCAVATED+TRANS TO (T-80, 2624)	NA
THE DPW WAS NOTIFIED OF ANY DISCHARGE TO THE ENVIRONMENT. (WHO) _____	NA
ALL PETROL. CONT. SOILS WERE SECURED FROM THE WEATHER BY CLOSE OF BUSINESS TODAY	NA
THE DPW AUTHORIZED BACKFILLING THE EXCAVATION. SSE INITIAL REQUIRED: _____	Y
THE UST WAS TRANSPORTED TO <u>BLOK 166</u> FOR DISPOSAL (ATTACH SCRAP TICKET)	Y
ADDITIONAL NOTES WERE TAKEN AND RECORDED ON THE BACK OF THIS FORM	N
THE FOLLOWING DOCUMENTS WERE GIVEN TO THE SSE TODAY: (CIRCLE EACH OR ADD ITEMS) _____	NA
SCRAP TICKET, CSE PERMIT, ACCIDENT REPORT, _____	NA

CHECK ALL BOXES, LEAVE NO BLANKS

I certify under penalty of law that tank decommissioning activities were performed in compliance with N.J.A.C. 7:14B-9.2(b)3. I am aware that there are significant penalties for submitting false, inaccurate, or incomplete information, including fines and/or imprisonment.

CLOSURE TECH (PRINT NAME): FRANK ACCORSI
 SIGNATURE: Frank Accorsi DATE: 1-3-00

U.S. ARMY FORT MONMOUTH
UST DATABASE INPUT FORM

SELEM-EH-EIV

DATE: 11/8/94 BUILDING #: 2240
NJDEPE REG. #: 81515 UST #: 10
PRODUCT: (#2), #6, DIESEL, GASOLINE, OTHER, _____
STATUS: IN USE, NOT IN USE AS OF 11, 8, 94
REASON NOT IN USE: GASIFICATION, LEAKER, DEMO
GENERAL COMMENTS:

UST PRODUCT REMOVED: DATE: 11/8/94
CONTRACTOR: SERV AIR P.O.L. T. Smythe
MANIFEST #: NONE
COMMENTS: 16 GALS WASTE IN TANK
118 GALS TO BLDG 2700

NJDEPE DISCHARGE TO ENVIRONMENT NOTIFICATION
(609) 292-7172;

CALLER NAME: _____

DATE: _____ TIME: _____

NJDEPE CASE NUMBER: _____

COMMENTS: _____

ATTACHMENTS (COPIES): HAZ-MAT MANIFEST.
LAND BAN SERVICE ORDER PURCHASE REQ
SPILL REPORT

SUBMITTED BY: _____

SIGNATURE: _____ DATE: _____

TVS
UTILITY MARKING REQUEST

Request marking of circled utility lines in the area indicated below.

NJ Nat. Gas Co.	Post Telephone
NJ Bell	Post water/sewer
NJ American Water Co.	Post Electric
JCP&L	Co. Sewage Auth.
Cable TV Co.	

COUNTY: Monmouth
TOWNSHIP: TINTON FALLS (See municipality list)
TOWN: Fort Monmouth
BUILDING NUMBER: 2240
STREET ADDRESS: 26+28 HEMPHILL RD.
NEAREST CROSS STREET: GUAM LANE, HOPE RD.
LOCATION OF EXCAVATION: BUILDING FRONT
(e.g. street, sidewalk, etc.)
DATE OF EXCAVATION: 11-2-99 0800
DEPTH OF EXCAVATION: 10 FT. MAX.
COMPANY NAME: TVS
COMPANY ADDRESS: P.O. Box 60
Ft. Monmouth, NJ 07703
S.O. / J.O. NUMBER: 100004
NAME OF REQUESTOR: FRANK ACCORSI
DATE OF REQUEST: 10-26-99
NAME OF CALLER: _____
DATE OF CALL: _____
MARKING NUMBER: 993000437

Approval for emergency digging without marking:

UNDERGROUND STORAGE TANK REMOVAL
(550 G.)

New # Fri 11/5 0800
993020979

New Jersey One Call System

SEQUENCE NUMBER 0008

SDC = FOM

Transmit: Date: 10/29/99 AP: 1420

*** R O U T I N E *** Request No.: 993020979

Operators Notified:

CC4=/COMCAS-MNMOUTH / NJN=/NJNG-UTILIQUEST/ NJA=/NJ AMER WTR /
GP9=/GPU ENERGY-CLS / BAN=/BELL ATL NJ-CLS/ FOM=/FORT MONMOUTH /

Location Information:

County: MONMOUTH Municipality: TINTON FALLS
Subdivision/Community: FORT MONMOUTH
Street: 26 - 28 HEMPHILL RD
Nearest Intersection: HOPE RD
Other Intersection: GUAM LN
Type of Work : REMOVE UST
Extent of Work: ENTIRE FRONT

DEPTH: 10FT

Location Reference:
FRONT-
Start Date/Time: 11/05/99 At 0800

Remarks:
EXPIRATION DATE 12/15/99
1 BLDG\2 UNITS BLDG 2240
CONSECUTIVE ODD ADDR IN SAME BLDG

Working For: TVS
Address: PO BOX 60
City: FORT MONMOUTH 07703
Phone: 732-532-6955
Contact: EILEEN MAIAR Title:

Excavator Information:

Caller: EILEEN MAIAR Title: WORK CNTRL
Phone: 732-532-6955

Excavator: TVS
Address: PO BOX 60
City: FORT MONMOUTH, NJ 07703
Phone: 732-532-6955 Fax: 732-542-1107
Contact: EILEEN MAIER Title: WORK CNTRL
Phone: 732-532-6955 Best Time: 0800-1600
Cellular:

Alternate Field Contact:
Name: FRANK ACCORSCK Title: SUBSRFC EV
Phone: 732-532-2577 Fax:
Cellular: Best Time: 0800-1600

End Request

New Jersey One Call System

SEQUENCE NUMBER 0007

CDC = FOM

Transmit: Date: 10/27/99 At: 0957

*** ROUTINE

*** Request No.: 993000437

Operators Notified:

CC4=/COMCAS-MNMOUTH / NJN=/NJNG-UTILIQUEST/ NJA=/NJ MER WTR /
GP9=/GPU ENERGY-CLS / BAN=/BELL ATL NJ-CLS/ FOM=/FORT MONMOUTH /

Location Information:

County: MONMOUTH Municipality: TINTON FALLS

Subdivision/Community: FORT MONMOUTH

Street: 27 HEMPHILL RD

Nearest Intersection: HOPE RD

Other Intersection: GUAM LN

Type of Work : REMOVE UST

Extent of Work: ENTIRE FRONT

DEPTH: 10FT

Location Reference:

FRONT-

Start Date/Time: 11/02/99 At 0800

Remarks:

EXPIRATION DATE 12/13/99

1 BLDG 2 UNITS BLG 2240

Working For: TVS

Address: PO BOX 60

City: FORT MONMOUTH 07703

Phone: 732-532-6955

Contact: EILEEN MAIAR

Title:

Excavator Information:

Caller: EILEEN MAIAR

Title: WORK CNTRL

Phone: 732-532-6955

Excavator: TVS

Address: PO BOX 60

City: FORT MONMOUTH, NJ 07703

Phone: 732-532-6955

Fax: 732-542-1107

Contact: EILEEN MAIAR

Title: WORK CNTRL

Phone: 732-532-6955

Best Time: 0800-1600

Cellular:

Alternate Field Contact:

Name: FRANK ACCORSO

Title: SUBSRFC EV

Phone: 732-532-2777

Fax:

Cellular:

Best Time: 0800-1600

End Request

ACL

DIRECTORATE OF PUBLIC WORKS
FORT MONMOUTH, NEW JERSEY 07703

Contract Management Division

SUBJECT: PWS-007, Residential UST Removal
Contractor: TVS Inc.

RE: Backfilling of excavation,


BUILDING #: 2240 (26+28 HEMPHILL RD)

TVS Inc.
Field Supervisor, PWS-007
ATTN: Brian Finch
Building 166
Fort Monmouth, New Jersey 07703-5000

Dear Mr. Finch:

The above referenced area has been sampled and analyzed as described in the NJDEP Regulations. The results indicate levels of petroleum contamination below the NJDEP allowable limits ~~or that the site requires further investigation outside the scope of this contract.~~ The contractor may proceed with the backfilling of the excavation with stone to groundwater and clean fill to grade as required in the above referenced contract specification.

Regards,


Mr. Dinker Desai
Environmental Engineer
Directorate of Public Works

CC: UST file copy

Report of Analysis
Fort Monmouth Environmental Laboratory
NJDEP Certification # 13461

Client: U.S. Army
DPW: SELFM-PW-EV
Bldg: 173
Ft. Monmouth, NJ 07703


Lab. ID #: 5057
Date Rec'd: 03-Jan-00
Analysis Start: 03-Jan-00
Analysis Complete: 03-Jan-00

Analysis: OQA-QAM-025
Matrix: Soil
Analyst: B.Patel
Inst. ID: GC TPHC INST. #1
Column Type: RTX 5
Ext. Meth: Shake

UST Reg. #: 81515-10
Closure #:
DICAR #:
Injection Volume: 1 ul
Column ID: 0.32 mm
Location #: Bldg.2240

Sample	Field ID	Dilution Factor	Weight (g)	% Solid	MDL (mg/kg)	TPHC Result (mg/kg)
5057.01	2240-A	1.00	15.01	81.87	191	ND
5057.02	2240-B	1.00	15.07	85.42	183	ND
5057.03	2240-C	1.00	15.33	82.53	186	ND
5057.04	2240-D	1.00	15.12	82.89	188	ND
METHOD BLANK	TBLK301	1.00	15.00	100.00	157	ND

ND = Not Detected
MDL = Method Detection Limit


Daniel A. Wright
Laboratory Director

FORT MONMOUTH ENVIRONMENTAL TESTING LABORATORY

DIRECTORATE OF PUBLIC WORKS

PHONE: (732) 632-6224 FAX: (732) 632-6263

WET-CHEM - METALS - ORGANICS - FIELD SAMPLING

CERTIFICATIONS: NJDEP #13461, NYS DOH #11699

ANALYTICAL DATA REPORT Fort Monmouth Environmental Laboratory ENVIRONMENTAL DIVISION Fort Monmouth, New Jersey PROJECT: IJO# 100004

Field Sample Location	Laboratory Sample ID#	Matrix	Date and Time of Collection	Date Received
2240-A West End 6.5-7'	5057.01	Soil	03-Jan-00 10:20	01/03/00
2240-B East End 6.5-7'	5057.02	Soil	03-Jan-00 10:40	01/03/00
2240-C Piping 1.5-2'	5057.03	Soil	03-Jan-00 11:00	01/03/00
2240-D Duplicate	5057.04	Soil	03-Jan-00 10:40	01/03/00
Trip Blank	5057.05	Methanol	03-Jan-00	01/03/00

FORT MONMOUTH ENVIRONMENTAL LAB TPHC, %SOLIDS

ENCLOSURE:
CHAIN OF CUSTODY
RESULTS


1-12-00
Daniel Wright/Date
Laboratory Director

Table of Content

Section	Page No.
Method Summary	1
Conformance/Non-Conformance Summary	2
Chain of Custody	3
Results Summary	4
Initial Calibration Summary	5
Continuing Calibration Summary	6
Surrogate Results Summary	10
MS/MSD Results Summary	11
Blank Spike Summary	12
Raw Sample Data	13
Laboratory Deliverable Checklist	23
Laboratory Authentication Statement	24

Method Summary

NJDEP Method OOA-QAM-025-10/97

Gas Chromatographic Determination of Total Petroleum Hydrocarbons in Soil

Fifteen grams (15g)(wet weight) of a soil sample is added to a 125 mL acid cleaned, solvent rinsed, capped Erlenmeyer flask. 15g anhydrous sodium sulfate is added to dry sample. Surrogate standard spiking solution is then added to the flask.

Twenty five milliliters(25mL) Methylene Chloride is added to the flask and it is secured on a orbital shaker table. The agitation rate is set to 400rpm and the sample is shaken for 30 minutes. The flask is the removed from the table and the particulate matter is allowed to settle. The extract is transferred to a Teflon capped vial. A second 25mL of Methylene Chloride is added to the flask and shaken for an additional 30 minutes. The flask is again removed and allowed to settle. The extracts are combined in the vial then transferred to a 1mL autosampler vial.

The extract is then injected directly into a GC-FID for analysis. The sample is analyzed for petroleum hydrocarbons covering a range of C8-C42 including pristane and phytane. Total Petroleum Hydrocarbon concentration is determined by integrating between 5 minutes and 22 minutes. The baseline is established by starting the integration after the end of the solvent peak and stopping after the last peak.

The final concentration of Total Petroleum Hydrocarbons is calculated using percent solid, sample weight and concentration.

000001

TPHC Conformance/Non-conformance Summary Report

- | | Indicate
Yes, No, N/A |
|---|--------------------------|
| 1. Method Detection Limits provided. | <u>Yes</u> |
| 2. Method Blank Contamination – If yes, list the sample and the corresponding concentrations in each blank.

_____ | <u>NO</u> |
| 3. Matrix Spike Results Summary Meet Criteria
(If not met, list the sample and corresponding recovery which falls outside the acceptable range).

_____ | <u>Yes</u> |
| 4. Duplicate Results Summary Meet Criteria
(If not met, list the sample and corresponding recovery which falls outside the acceptable range).

_____ | <u>Yes</u> |
| 5. IR Spectra submitted for standards, blanks and samples. | <u>NA</u> |
| 6. Chromatograms submitted for standards, blanks and samples if GC fingerprinting was conducted. | <u>Yes</u> |
| 7. Analysis holding time met.
(If not met, list number of days exceeded for each sample).

_____ | <u>Yes</u> |

Additional comments: _____



Laboratory Manager

1-12-00

Date

000002



Fort Monmouth Environmental Testing Laboratory

Bldg. 173, SELFM-PW-EV, Fort Monmouth, NJ 07703

Tel (732)532-4359 Fax (732)532-6263 EMail: appleby@mail1.monmouth.army.mil

NJDEP Certification #13461

Chain of Custody Record

Customer: Dinker Desai				Project No: 100004				Analysis Parameters				Comments:	
Phone #: X21475				Location: BLDG. 2240								* = Samples Kept <4°C	
() DERA (X) OMA UST Assessment				UST# 81515-10									
Samplers Name / Company : Frank Accorsi/TVS								Sample	#			PID Reading	Remarks / Preservation Method
Lab Sample I.D.	Sample Location			Date	Time	Type	bottles	TPHC	% SOLIDS	VOA+10	VOA ID #		
S057 01	2240-A, WEST END, 6.5-7 FT			1-3-00	1020	SOIL	2	X	X	X	281	0	ICE
02	2240-B, EAST END, 6.5-7 FT				1040		2	X	X	X	282	0	
03	2240-C, PIPING, 1.5-2 FT				1100		2	X	X	X	283	0	
04	2240-D, DUPLICATE				1040		2	X	X	X	284	0	
05	TRIP BLANK				-	AQ	1			X	285	1	
OVM sn#580U-64455.343 was calibrated with zero air & w/245 ppm Isobutylene read 245 ppm. 1000 1-3-00 (time/date & initial)													
Relinquished by (signature):		Date/Time:		Received by (signature):		Relinquished by (signature):		Date/Time:					
<i>Frank Accorsi</i>		1-3-00 1140		<i>J. Hannon</i>									
Relinquished by (signature):		Date/Time:		Received by (signature):		Relinquished by (signature):		Date/Time:					
Report Type: () Full, () Reduced, (X) Standard, () Screen / non-certified, () EDD								Remarks: Dedicated Sampling Tools Used					
Turnaround time: () Standard 2 wks, (X) Rush 1 Days, () ASAP Verbal Hrs.								All sample points have been GPS? (X) YES () NO () NA					

0003

SAMPLE RECEIPT FORM

Date Received: 1/3/00

Lab Project ID#: 5057

Site/Project Name: Bldg 2240

Cooler Temp (°C): 40

Received By: J. Hansen
(print name)

Sign: J. Hansen

Check the appropriate answer

- | | | | |
|---|---|-----------------------------|-----------------------------|
| 1. Did the samples come in a cooler? | <input checked="" type="checkbox"/> yes | <input type="checkbox"/> no | <input type="checkbox"/> NA |
| 2. Were the chain of custody papers filled out correctly and legibly? | <input checked="" type="checkbox"/> yes | <input type="checkbox"/> no | |
| 3. Did you sign the chain of custody in the appropriate place? | <input checked="" type="checkbox"/> yes | <input type="checkbox"/> no | |
| 4. Did all the labels agree with the chain of custody and in good condition? | <input checked="" type="checkbox"/> yes | <input type="checkbox"/> no | |
| 5. Were the correct containers and/or preservatives used for the tests indicated? | <input checked="" type="checkbox"/> yes | <input type="checkbox"/> no | |
| 6. Was a sufficient amount of sample sent for the tests indicated? | <input checked="" type="checkbox"/> yes | <input type="checkbox"/> no | |
| 7. Were bubbles absent from aqueous VOC sample containers? | <input checked="" type="checkbox"/> yes | <input type="checkbox"/> no | <input type="checkbox"/> NA |
| 8. Were samples received on ice? | <input checked="" type="checkbox"/> yes | <input type="checkbox"/> no | |

Fill out the following table for each sample bottle

Sample ID	pH	Preservative	Sample ID	pH	Preservative

Comments: _____

Report of Analysis
U.S. Army, Fort Monmouth Environmental Laboratory
NJDEP Certification # 13461

Client : U.S. Army
 DPW. SELFM-PW-EV
 Bldg. 173
 Ft. Monmouth, NJ 07703

Lab. ID # : 5057
Date Rec'd: 03-Jan-00
Analysis Start: 03-Jan-00
Analysis Complete: 03-Jan-00


Analysis: OQA-QAM-025
Matrix: Soil
Analyst: B.Patel
Inst. ID. GC TPHC INST. #1
Column Type RTX 5
Ext. Meth: Shake

UST Reg. #: 81515-10
Closure #:
DICAR #:
Injection Volume 1 ul
Column ID 0.32 mm
Location #: Bldg.2240

Sample	Field ID	Dilution Factor	Weight (g)	% Solid	MDL (mg/kg)	TPHC Result (mg/kg)
5057.01	2240-A	1.00	15.01	81.87	191	ND
5057.02	2240-B	1.00	15.07	85.42	183	ND
5057.03	2240-C	1.00	15.33	82.53	186	ND
5057.04	2240-D	1.00	15.12	82.89	188	ND
METHOD BLANK	TBLK301	1.00	15.00	100.00	157	ND

ND = Not Detected

MDL = Method Detection Limit


 Daniel K. Wright
 Laboratory Director

Response Factor Report GC/MS

Method : C:\HPCHEM\1\METHODS\TPH70.M (Chemstation Integrator)
 Title : TPHC Calibration 06/05/97 21 peaks
 Last Update : Thu Dec 30 08:37:14 1999

Calibration Files

100 =T009501.D 50 =T009495.D 20 =T009497.D
 10 =T009498.D 5 =T009502.D

Compound	100	50	20	10	5	Avg	%RSD
1) tC C8	2.193	2.099	2.050	2.038	1.809	2.038 E4	6.94
2) tC C10	2.222	2.269	2.122	2.089	1.792	2.099 E4	8.88
3) TC C12	2.215	2.290	2.140	2.118	1.802	2.113 E4	8.83
4) tC C14	2.250	2.326	2.182	2.080	1.939	2.155 E4	7.02
5) tC C16	2.259	2.349	2.187	2.186	1.942	2.185 E4	6.91
6) tC C18	2.098	2.240	2.182	2.033	1.754	2.061 E4	9.17
7) tC C20	2.259	2.371	2.154	2.113	1.931	2.166 E4	7.63
8) tC C22	2.352	2.477	2.298	2.320	2.087	2.307 E4	6.11
9) tC C24	2.353	2.475	2.306	2.343	2.072	2.310 E4	6.37
10) tC C26	2.342	2.460	2.318	2.313	2.072	2.301 E4	6.14
11) tC C28	2.333	2.440	2.269	2.288	2.023	2.271 E4	6.76
12) tC C30	2.426	2.555	2.391	2.268	2.158	2.360 E4	6.44
13) tC C32	2.343	2.449	2.239	2.230	1.953	2.243 E4	8.25
14) tC C34	2.331	2.449	2.209	2.221	1.945	2.231 E4	8.38
15) tC C36	2.282	2.402	2.189	2.178	1.871	2.184 E4	9.01
16) tC C38	2.268	2.411	2.176	2.182	1.878	2.183 E4	8.93
17) tC C40	2.098	2.223	2.030	2.031	1.711	2.019 E4	9.37
18) tC c42	2.116	2.267	2.046	2.049	1.731	2.042 E4	9.58
19) TC Pristane	2.411	2.470	2.402	2.487	2.292	2.412 E4	3.18
20) TC Phytane	2.291	2.443	2.245	2.226	2.200	2.281 E4	4.23
21) sC o-terphenyl	2.677	2.808	2.609	2.643	2.383	2.624 E4	5.89
22) tC TPHC - total	2.843	2.960	3.098	3.660	3.801	3.272 E4	13.16

000005

Evaluate Continuing Calibration Report

Data File : C:\HPCHEM\1\DAT J0103\T009565.D
 Acq On : 3 Jan 2000 2:20 pm
 Sample : Tstd050
 Misc : 50 ppm std
 IntFile : TPHCINT.E

Vial :
 Operator: Bhaskar
 Inst : GC/MS Ins
 Multiplr: 1.00

Method : C:\HPCHEM\1\METHODS\TPH70.M (Chemstation Integrator)
 Title : TPHC Calibration 06/05/97 21 peaks
 Last Update : Thu Dec 30 08:37:14 1999
 Response via : Multiple Level Calibration

Min. RRF : 0.000 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
 Max. RRF Dev : 15% Max. Rel. Area : 200%

Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)
1 tC C8	20.377	22.150 E3	-8.7	106	-0.06
2 tC C10	20.990	22.702 E3	-8.2	100	0.00
3 TC C12	21.131	22.500 E3	-6.5	98	0.00
4 tC C14	21.554	22.982 E3	-6.6	99	0.00
5 tC C16	21.847	22.956 E3	-5.1	98	0.00
6 tC C18	20.614	21.268 E3	-3.2	95	0.00
7 tC C20	21.656	22.780 E3	-5.2	96	0.00
8 tC C22	23.070	23.795 E3	-3.1	96	0.00
9 tC C24	23.098	23.666 E3	-2.5	96	0.00
10 tC C26	23.012	23.460 E3	-1.9	95	0.00
11 tC C28	22.706	23.205 E3	-2.2	95	0.00
12 tC C30	23.597	24.074 E3	-2.0	94	0.00
13 tC C32	22.427	23.047 E3	-2.8	94	0.00
14 tC C34	22.312	22.745 E3	-1.9	93	0.00
15 tC C36	21.845	22.187 E3	-1.6	92	-0.01
16 tC C38	21.829	21.473 E3	1.6	89	-0.02
17 tC C40	20.186	18.931 E3	6.2	85	-0.03
18 tC c42	20.418	18.244 E3	10.6	80	-0.05
19 TC Pristane	24.122	24.402 E3	-1.2	99	0.00
20 TC Phytane	22.810	23.241 E3	-1.9	95	0.00
21 sC o-terphenyl	26.240	27.601 E3	-5.2	98	0.00
22 tC TPHC - total	32.725	32.584 E3	0.4	110	0.00

Evaluation/Continuing Calibration Report

Data File : C:\HPCHEM\1\DATA\ J0103\T009574.D
 Acq On : 3 Jan 2000 8:25 pm
 Sample : Tstd050
 Misc : 50 ppm std.
 IntFile : TPHCINT.E

Via. 0
 Operator: Bhaskar
 Inst : GC/MS Ins
 Multiplr: 1.00

Method : C:\HPCHEM\1\METHODS\TPH70.M (Chemstation Integrator)
 Title : TPHC Calibration 06/05/97 21 peaks
 Last Update : Thu Dec 30 08:37:14 1999
 Response via : Multiple Level Calibration

Min. RRF : 0.000 Min. Rel. Area : 50% Max. R.T. Dev 0.50min
 Max. RRF Dev : 15% Max. Rel. Area : 200%

Compound	AvgRF	CCRF	%Dev	Area%	Dev(min)
1 tC C8	20.377	23.324 E3	-14.5	111	-0.06
2 tC C10	20.990	23.307 E3	-11.0	103	0.00
3 TC C12	21.131	23.040 E3	-9.0	101	0.00
4 tC C14	21.554	23.394 E3	-8.5	101	0.00
5 tC C16	21.847	23.425 E3	-7.2	100	0.00
6 tC C18	20.614	23.291 E3	-13.0	104	0.00
7 tC C20	21.656	23.168 E3	-7.0	98	0.00
8 tC C22	23.070	24.385 E3	-5.7	98	0.00
9 tC C24	23.098	24.267 E3	-5.1	98	0.00
10 tC C26	23.012	24.064 E3	-4.6	98	0.00
11 tC C28	22.706	23.881 E3	-5.2	98	0.00
12 tC C30	23.597	24.752 E3	-4.9	97	0.00
13 tC C32	22.427	23.599 E3	-5.2	96	0.00
14 tC C34	22.312	23.255 E3	-4.2	95	-0.01
15 tC C36	21.845	22.739 E3	-4.1	95	-0.02
16 tC C38	21.829	22.401 E3	-2.6	93	-0.02
17 tC C40	20.186	20.198 E3	-0.1	91	-0.04
18 tC c42	20.418	19.706 E3	3.5	87	-0.05
19 TC Pristane	24.122	24.367 E3	-1.0	99	0.00
20 TC Phytane	22.810	23.658 E3	-3.7	97	0.00
21 sC o-terphenyl	26.240	28.040 E3	-6.9	100	0.00
22 tC TPHC - total	32.725	29.854 E3	8.8	101	0.00

Data File : C:\HPCHEM\1\LA\A\000103\T009566.D
Acq On : 3 Jan 2000 3:44 pm
Sample : TBLK301
Misc : TBLK301 S 000103
IntFile : TPHCINT.E
Quant Time: Jan 3 16:12 2000 Quant Results File: TPH70.RES

Vol: 2
Operator: Bhaskar
Inst : GC/MS Ins
Multiplr: 1.00

Quant Method : C:\HPCHEM\1\METHODS\TPH70.M (Chemstation Integrator)
Title : TPHC Calibration 06/05/97 21 peaks
Last Update : Thu Dec 30 08:37:14 1999
Response via : Initial Calibration
DataAcq Meth : TPH70.M

Volume Inj. : 1 ul
Signal Phase : HP-5
Signal Info : 30m x 0.32mm

Compound	R.T.	Response	Conc Units
System Monitoring Compounds			
21) sC o-terphenyl	12.61	252270	9.614 mg/L
Spiked Amount 10.000	Range 8 - 13	Recovery =	96.14%#

Target Compounds

000008

Quantitation Report

Data File : C:\HPCHEM\1\...A\000103\T009566.D

Acq On : 3 Jan 2000 3:44 pm

Sample : TBLK301

Misc : TBLK301 S 000103

IntFile : TPHCINT.E

Quant Time: Jan 3 16:12 2000 Quant Results File: TPH70.RES

1: 2

Operator: Bhaskar

Inst : GC/MS Ins

Multiplr: 1.00

Quant Method : C:\HPCHEM\1\METHODS\TPH70.M (Chemstation Integrator)

Title : TPHC Calibration 06/05/97 21 peaks

Last Update : Thu Dec 30 08:37:14 1999


Response via : Multiple Level Calibration

DataAcq Meth : TPH70.M

Volume Inj. : 1 ul

Signal Phase : HP-5

Signal Info : 30m x 0.32mm



001009

Surrogate Recovery Report
U.S. Army, Fort Monmouth Environmental Laboratory
NJDEP Certification # 13461

Client :	U.S. Army	Lab. ID # :	5057
	DPW. SELFM-PW-EV	Date Rec'd:	03-Jan-00
	Bldg. 173	Analysis Start:	03-Jan-00
	Ft. Monmouth, NJ 07703	Analysis Complete:	03-Jan-00
		UST Reg. #:	81515-10
Analysis:	OQA-QAM-025	Closure #:	
Matrix:	Soil	DICAR #:	
Analyst:	B.Patel	Injection Volume	1 ul
Inst. ID.	GC TPHC INST. #1	Column ID	0.32 mm
Column Type	RTX 5	Location #:	Bldg.2240
Ext. Meth:	Shake		

Sample			Surrogate Added (ppm)	Amount Recovered (ppm)	Percent Recovery
5057.01			10.00	10.49	104.85
5057.02			10.00	10.30	103.00
5057.03			10.00	10.08	100.77
5057.04			10.00	10.40	103.95
METHOD BLANK	TBLK301		10.00	9.61	96.14

Surrogate Added : o-Terphenyl

Matrix Spike/ Duplicate Recovery Report
U.S.Army, Fort Monmouth Environmental Laboratory
NJDEP Certification # 13461

Client :	U.S. Army	Lab. ID # :	5057
	DPW. SELFM-PW-EV	Date Rec'd:	03-Jan-00
	Bldg. 173	Analysis Start:	03-Jan-00
	Ft. Monmouth, NJ 07703	Analysis Complete:	03-Jan-00
Analysis:	OQA-QAM-025	UST Reg. #:	81515-10
Matrix:	Soil	Closure #:	
Analyst:	B.Patel	DICAR #:	
Inst. ID.	GC TPHC INST. #1	Injection Volume	1 ul
Column Type	RTX 5	Column ID	0.32 mm
Ext. Meth:	Shake	Location #:	Bldg.2240

Sample	Spike Amount Added (ppm)	Sample Amount (ppm)	Matrix Spike Amount (ppm)	Percent Recovery	QC Limits %
5057.04MS	1000	0.00	848.77	84.88	75-125
5057.04MSD	1000	0.00	854.44	85.44	75-125

RPD	0.67	20.00
-----	------	-------

000011

Quality Control Check Standard Summary
U.S.Army, Fort Monmouth Environmental Laboratory
NJDEP Certification # 13461

Client :	U.S. Army	Lab. ID # :	5057
	DPW. SELFM-PW-EV	Date Rec'd:	03-Jan-00
	Bldg. 173	Analysis Start:	03-Jan-00
	Ft. Monmouth, NJ 07703	Analysis Complete:	03-Jan-00
Analysis:	OQA-QAM-025	UST Reg. #:	81515-10
Matrix:	Soil	Closure #:	
Analyst:	B.Patel	DICAR #:	
Inst. ID.	GC TPHC INST. #1	Injection Volume	1 ul
Column Type	RTX 5	Column ID	0.32 mm
Ext. Meth:	Shake	Location #:	Bldg.2240

Sample	Date Extracted	Spike Amount Added (ppm)	Matrix Spike Amount (ppm)	Percent Recovery	QC Limits %
Tblk301BS	03-Jan-00	1000	901.20	90.12	75-125

Data File : C:\HPCHEM\1\000103\T009567.D
 Acq On : 3 Jan 2000 4:19 pm
 Sample : TBLK301BS
 Misc : TBLK301BS S 000103
 IntFile : TPHCINT.E
 Quant Time: Jan 4 9:08 2000 Quant Results File: TPH70.RES
 Operator: Bhaskar
 Inst : GC/MS Ins
 Multiplr: 1.00

Quant Method : C:\HPCHEM\1\METHODS\TPH70.M (Chemstation Integrator)
 Title : TPHC Calibration 06/05/97 21 peaks
 Last Update : Thu Dec 30 08:37:14 1999
 Response via : Initial Calibration
 DataAcq Meth : TPH70.M

Volume Inj. : 1 ul
 Signal Phase : HP-5
 Signal Info : 30m x 0.32mm

Compound	R.T.	Response	Conc Units
System Monitoring Compounds			
21) sC o-terphenyl	12.61	262870	10.018 mg/L
Spiked Amount 10.000	Range 8 - 13	Recovery =	100.18%#
Target Compounds			
2) tC C10	7.29	157161	7.488 mg/L
3) TC C12	8.98	421381	19.942 mg/L
4) tC C14	10.16	423490	19.647 mg/L
5) tC C16	11.17	357373	16.358 mg/L
6) tC C18	11.63	232365	11.272 mg/L
7) tC C20	12.07	232700	10.745 mg/L
8) tC C22	12.88	127238	5.515 mg/L
9) tC C24	13.63	55864	2.419 mg/L
19) TC Pristane	11.63	232365	9.633 mg/L
20) TC Phytane	12.11	99830	4.377 mg/L
22) tC TPHC - total	10.16	29491641	901.202 mg/L m

000013


Quantitation Report

Data File : C:\HPCHEM\1\000103\T009567.D
Acq On : 3 Jan 2000 4:19 pm
Sample : TBLK301BS
Misc : TBLK301BS S 000103
IntFile : TPHCINT.E
Quant Time: Jan 4 9:08 2000 Quant Results File: TPH70.RES

Operator: Bhaskar
Inst : GC/MS Ins
Multiplr: 1.00

Quant Method : C:\HPCHEM\1\METHODS\TPH70.M (Chemstation Integrator)
Title : TPHC Calibration 06/05/97 21 peaks
Last Update : Thu Dec 30 08:37:14 1999
Response via : Multiple Level Calibration
DataAcq Meth : TPH70.M

Volume Inj. : 1 ul
Signal Phase : HP-5
Signal Info : 30m x 0.32mm



Data File : C:\HPCHEM\1\000103\T009568.D
Acq On : 3 Jan 2000 4:54 pm
Sample : 5057.01s
Misc :
IntFile : TPHCINT.E
Quant Time: Jan 4 9:09 2000 Quant Results File: TPH70.RES

1: 4
Operator: Bhaskar
Inst : GC/MS Ins
Multiplr: 1.00

Quant Method : C:\HPCHEM\1\METHODS\TPH70.M (Chemstation Integrator)
Title : TPHC Calibration 06/05/97 21 peaks
Last Update : Thu Dec 30 08:37:14 1999
Response via : Initial Calibration
DataAcq Meth : TPH70.M

Volume Inj. : 1 ul
Signal Phase : HP-5
Signal Info : 30m x 0.32mm

Compound	R.T.	Response	Conc Units
System Monitoring Compounds			
21) sC o-terphenyl	12.61	275122	10.485 mg/L
Spiked Amount 10.000	Range 8 - 13	Recovery =	104.85%#
Target Compounds			
22) tC TPHC - total	12.61	1395756	42.651 mg/L m

000015


Quantitation Report

Data File : C:\HPCHEM\1\000103\T009568.D
Acq On : 3 Jan 2000 4:54 pm
Sample : 5057.01s
Misc :
IntFile : TPHCINT.E
Quant Time: Jan 4 9:09 2000 Quant Results File: TPH70.RES

Operator: Bhaskar
Inst : GC/MS Ins
Multiplr: 1.00

Quant Method : C:\HPCHEM\1\METHODS\TPH70.M (Chemstation Integrator)
Title : TPHC Calibration 06/05/97 21 peaks
Last Update : Thu Dec 30 08:37:14 1999
Response via : Multiple Level Calibration
DataAcq Meth : TPH70.M

Volume Inj. : 1 ul
Signal Phase : HP-5
Signal Info : 30m x 0.32mm



Data File : C:\HPCHEM\1\A000103\T009569.D
 Acq On : 3 Jan 2000 5:30 pm
 Sample : 5057.02s
 Misc :
 IntFile : TPHCINT.E
 Quant Time: Jan 4 9:09 2000 Quant Results File: TPH70.RES

1: 5
 Operator: Bhaskar
 Inst : GC/MS Ins
 Multiplr: 1.00

Quant Method : C:\HPCHEM\1\METHODS\TPH70.M (Chemstation,Integrator)
 Title : TPHC Calibration 06/05/97 21 peaks
 Last Update : Thu Dec 30 08:37:14 1999
 Response via : Initial Calibration
 DataAcq Meth : TPH70.M

Volume Inj. : 1 ul
 Signal Phase : HP-5
 Signal Info : 30m x 0.32mm

Compound	R.T.	Response	Conc Units
----------	------	----------	------------

System Monitoring Compounds

21) sC o-terphenyl	12.61	270268	10.300 mg/L
Spiked Amount 10.000	Range 8 - 13	Recovery =	103.00%#

Target Compounds

000017


Quantitation Report

Data File : C:\HPCHEM\1\T009569.D
Acq On : 3 Jan 2000 5:30 pm
Sample : 5057.02s
Misc :
IntFile : TPHCINT.E
Quant Time: Jan 4 9:09 2000 Quant Results File: TPH70.RES

1: 5
Operator: Bhaskar
Inst : GC/MS Ins
Multiplr: 1.00

Quant Method : C:\HPCHEM\1\METHODS\TPH70.M (Chemstation Integrator)
Title : TPHC Calibration 06/05/97 21 peaks
Last Update : Thu Dec 30 08:37:14 1999
Response via : Multiple Level Calibration
DataAcq Meth : TPH70.M

Volume Inj. : 1 ul
Signal Phase : HP-5
Signal Info : 30m x 0.32mm



Data File : C:\HPCHEM\1\000103\T009570.D
Acq On : 3 Jan 2000 6:05 pm
Sample : 5057.03s
Misc :
IntFile : TPHCINT.E
Quant Time: Jan 4 9:09 2000 Quant Results File: TPH70.RES

1: 6
Operator: Bhaskar
Inst : GC/MS Ins
Multiplr: 1.00

Quant Method : C:\HPCHEM\1\METHODS\TPH70.M (Chemstation Integrator)
Title : TPHC Calibration 06/05/97 21 peaks
Last Update : Thu Dec 30 08:37:14 1999
Response via : Initial Calibration
DataAcq Meth : TPH70.M

Volume Inj: : 1 ul
Signal Phase : HP-5
Signal Info : 30m x 0.32mm

Compound	R.T.	Response	Conc Units
----------	------	----------	------------

System Monitoring Compounds

21) sC o-terphenyl	12.61	264409	10.077 mg/L
Spiked Amount	10.000	Range 8 - 13	Recovery = 100.77%#

Target Compounds

000019


Data File : C:\HPCHEM\1\DATA\000103\T009570.D
Acq On : 3 Jan 2000 6:05 pm
Sample : 5057.03s
Misc :
IntFile : TPHCINT.E
Quant Time: Jan 4 9:09 2000 Quant Results File: TPH70.RES

Operator: Bhaskar
Inst : GC/MS Ins
Multiplr: 1.00

Quant Method : C:\HPCHEM\1\METHODS\TPH70.M (Chemstation Integrator)
Title : TPHC Calibration 06/05/97 21 peaks
Last-Update : Dec 30 08:37:14 1999
Response via : Triple Level Calibration
DataAcq Meth : TP 70.M

Volume Inj. : 1 ul
Signal Phase : HP 5
Signal Info. : 30m x 0.32mm

T009570.D\FID1B



Data File : C:\HPCHEM\1\A\000103\T009571.D
 Acq On : 3 Jan 2000 6:39 pm
 Sample : 5057.04s
 Misc :
 IntFile : TPHCINT.E
 Quant Time: Jan 4 9:09 2000 Quant Results File: TPH70.RES
 Operator: Bhaskar
 Inst : GC/MS Ins
 Multiplr: 1.00

Quant Method : C:\HPCHEM\1\METHODS\TPH70.M (Chemstation Integrator)
 Title : TPHC Calibration 06/05/97 21 peaks
 Last Update : Thu Dec 30 08:37:14 1999
 Response via : Initial Calibration
 DataAcq Meth : TPH70.M

Volume Inj. : 1 ul
 Signal Phase : HP-5
 Signal Info : 30m x 0.32mm

Compound	R.T.	Response	Conc Units
System Monitoring Compounds			
21) sC o-terphenyl	12.61	272758	10.395 mg/L
Spiked Amount	10.000	Range 8 - 13	Recovery = 103.95%#

Target Compounds

000021

Quantitation Report

Data File : C:\HPCHEM\1\A\000103\T009571.D
Acq On : 3 Jan 2000 6:39 pm
Sample : 5057.04s
Misc :
IntFile : TPHCINT.E


A\000103\T009571.D

Operator: Bhaskar
Inst : GC/MS Ins
Multiplr: 1.00

Quant Time: Jan 4 9:09 2000 Quant Results File: TPH70.RES

Quant Method : C:\HPCHEM\1\METHODS\TPH70.M (Chemstation Integrator)
Title : TPHC Calibration 06/05/97 21 peaks
Last Update : Thu Dec 30 08:37:14 1999
Response via : Multiple Level Calibration
DataAcq Meth : TPH70.M

Volume Inj. : 1 ul
Signal Phase : HP-5
Signal Info : 30m x 0.32mm



000022


LABORATORY DELIVERABLES CHECKLIST AND NON-CONFORMANCE SUMMARY

THIS FORM MUST BE COMPLETED BY THE LABORATORY OR ENVIRONMENTAL CONSULTANT AND ACCOMPANY ALL DATA SUBMISSIONS

The following Laboratory Deliverables checklist and Non-Conformance Summary shall be included in the data submission. All deviations from the accepted methodology and procedures, of performance values outside acceptable ranges shall be summarized in the Non-Conformance Summary. The Technical Requirements for Site Remediation, effective June 7, 1993, provides further details. The document shall be bound and paginated, contain a table of contents, and all pages shall be legible. Incomplete packages will be returned or held without review until the data package is completed.

It is recommended that the analytical results summary sheets listing all targeted and non-targeted compounds with the method detection limits, practical quantitation limits, and the laboratory and/or sample numbers be included in one section of the data package and in the main body of the report.

- 1. Cover page, Title Page listing Lab Certification #, facility name and address, & date of report submitted
- 2. Table of Contents submitted
- 3. Summary Sheets listing analytical results for all targeted and non-targeted compounds submitted
- 4. Document paginated and legible
- 5. Chain of Custody submitted
- 6. Samples submitted to lab within 48 hours of sample collection.
- 7. Methodology Summary submitted
- 8. Laboratory Chronicle and Holding Time Check submitted
- 9. Results submitted on a dry weight basis
- 10. Method Detection Limits submitted
- 11. Lab certified by NJDEP for parameters of appropriate category of parameters or a member of the USEPA CLP

Laboratory Manager or Environmental Consultant's Signature 
Date 1/12/00

Laboratory Certification #13461

*Refer to NJAC 7:26E - Appendix A, Section IV - Reduced Data Deliverables - Non-USEPA/CLP Methods for further guidance.

Laboratory Authentication Statement

I certify under penalty of law, where applicable, that this laboratory meets the Laboratory Performance Standards and Quality Control requirements specified in N.J.A.C. 7:18 and 40 CFR Part 136 for Water and Wastewater Analyses and SW-846 for Solid Waste Analysis. I have personally examined the information contained in this report and to the best of my knowledge, I believe that the submitted information is true, accurate, complete and meets the above referenced standards where applicable. I am aware that there are significant penalties for purposefully submitting falsified information, including the possibility of a fine and imprisonment.



Daniel K. Wright
Laboratory Manager